

ADDEUNDUM #2
GLENDALE ROAD CULVERT REPLACEMENT
April 11, 2024

The number of this Addendum, Addendum No. 2, must be entered in the space provided on the Bid Form.

QUESTIONS FROM THE PRE-BID SITE WALK (APRIL 9, 2024)

Question 1:

Q: Where will the proposed utility pole be located?

A: Approximate location is shown on Sheet 4 of the Construction Drawings. Final location to be determined by National Grid Electric.

Question 2:

Q: What is the required design storm that the Control of Water system must be designed for?

A: The Control of Water system shall be designed for the 2-year design storm. Contractor's attention is directed to table on Sheet 2 of the Construction Drawings, and the Hydraulic Report prepared by Bay Colony Group.

Question 3:

Q: Who will supply the wetland specialist as part of the proposed wetland replication?

A: The Contractor is responsible for providing a wetland specialist. The cost of the wetland specialist shall be considered incidental to Item 755.01.

Question 4:

Q: Is there a defined maximum road closure window?

A: No.

**Glendale Road Culvert Replacement
Boxford, MA
April 9, 2024**

Pre-Bid Site Walk – Attendance List

NAME	COMPANY	EMAIL ADDRESS
Adam Lundsted	SumCo Eco-Contracting	alundstead@sumcoeco.com
Dan Gilgun	ET&L Corp.	etlinfo@etlcorp.com
James Learned	R. Bates & Sons, Inc.	jcl@rbatesconstruction.com
William Barr	Kodiak Corporation	cbarr@kodiakcorporation.com
Dan Galante	T. Ford	dan@tford.com
Andrew Spurr	TEC, Inc.	aspurr@theengineeringcorp.com
Matt Miloro	TEC, Inc.	mmiloro@theengineeringcorp.com
Chris Olbrot	Town of Boxford	colbrot@town.boxford.ma.us