



Jean M. Lorizio, Esq.  
Commission Chairman

**Commonwealth Of Massachusetts  
Alcoholic Beverages Control Commission  
95 Fourth Street, Suite 3  
Chelsea, MA 02150-2358**

**2023  
Retail License Renewal**

License Number: 06309-GP-0124

Municipality: BOXFORD

License Name : BOXFORD COMMUNITY KITCHEN  
INC.

License Class: Annual

License Type: General On-Premises

DBA :

Premise Address: 7 Elm Street Boxford, MA 01921

License Category: Wines and Malt

Manager: David Merrill

I hereby certify and swear under penalties of perjury that:

1. I am authorized to sign this renewal pursuant to M.G.L. Chapter 138;
2. The renewed license is of the same class, type, category as listed above;
3. The licensee has complied with all laws of the Commonwealth relating to taxes; and
4. The premises are now open for business (if not, explain below).

*Signature*

*10/19/22*

Signature

Date

*DAVID MERRILL*

*owner*

Printed Name

Title

Additional Information:

**Please complete and return this form to the Local Licensing Authority.**





# The Commonwealth of Massachusetts

Town of Boxford

## New and Renewal Certificate of Inspection

In accordance with 780 CMR, Chapter 1 (*The Eight Edition of the Massachusetts State Building Code*) and Chapter 304 of the Acts of 2004 (*an Act to further enhance fire and life safety*), this certificate of inspection is issued to the premise or structure or part thereof as herein identified.

Issued to		Identify Name of Establishment			Certificate No.
		BOXFORD COMMUNITY STORE			B22-10
Located at		Identify property address including street number, name, city or town and county			
		7 ELM STREET			
Use Group Classification(s)	1 <sup>st</sup> Floor	Second Floor	Second Floor	Second Floor	Other
			B		
Allowable Occupant Load			<45		

This certificate of inspection is hereby issued by the undersigned to certify that the premise, structure or portion thereof as herein specified has been inspected for general fire and life safety features. This certificate shall be framed behind clear glass and/or laminated and posted in a conspicuous place within the space as directed by the undersigned. Failure to post or tampering with the contents of the certificate is strictly prohibited.

Name of Municipal Fire Chief	Brian Geiger	Name of Municipal Building Commissioner	Peter J. Delaney	Date of Inspection	10/20/2022
Signature of Municipal Fire Chief		Signature of Municipal Building Commissioner	<i>Peter J. Delaney</i>	Date of Issuance	11-2-2022





**Boxford Fire Department  
6 MIDDLETON ROAD  
BOXFORD, MA 01921**



**Inspection Findings Report**

**Section Information**

Inspection #: 2022-34 STORE : EAST (COMMUNITY): 7 ELM STREET BOXFORD MA 01921 ( ) 887-5632 N/A

Inspection Date: 10/18/2022

Structure/Property: ELM STREET, 7  
7 ELM STREET BOXFORD MA 01921

Inspection ID: IN Inspection Reference ID:  
Inspection Status: Inspection Status Date: 10/18/2022  
Inspection Type: ANNUAL Inspection Conducted Date: 10/18/2022

The Boxford Fire Department conducted a fire safety inspection at the location and date referenced above. As result of this the inspection I have enclosed/attached the fire departments - Field Fire Safety Inspection Report.

**Inspection Findings/Action Requested**

- Item #: 1 Electric Panels  
Action Requested: Correct Immediately  
Notes/Comments: BASEMENT- CLEAR 3' AREA TO ELECTRICAL PANELS / Per 110.26 Access and working space shall be provided and maintained about all electrical equipment to permit ready and safe operation of maintenance of such equipment to a minimum of 30" in width and depth.  
Reference/Rationale: NFPA 70  
110.26 Spaces About Electrical Equipment
- #: 2 Storage Under Stairs  
Action Requested: Correct Immediately  
Notes/Comments: REMOVE GREASE TRAP & CLUTTER FROM UNDER STAIRS / Per 14.6.3 \* Usable Space.  
Enclosed, usable spaces, within exit enclosures shall be prohibited, including under stairs, unless otherwise permitted  
By 14.6.3.2. [101:7.2.2.5.3]  
Reference/Rationale: 527 CMR 1 Chapter 14 Means of Egress  
14.6 Enclosure and Protection of Stairs
- Item #: 3 Fire Extinguisher Types  
Action Requested: Add To Become Compliant  
Notes/Comments: PROPERLY POST SIGNAGE AND MOUNT ALL FIRE EXTINGUISHERS / Per Chapter 13 The appropriate fire extuinguishers and sizes must be installed properly according to code.  
Reference/Rationale: 527 CMR 1 Fire Protection Systems  
13.6 Portable Fire Extuinguishers
- Item #: 4 Fire Extinguisher Inspection  
Action Requested: Inspection By Proper Authority  
Notes/Comments: KEEP ANSUL SYSTEM AND HOOD UP TO DATE  
(ANSUL SERVICED JUNE '22)  
(HOOD SERVICED MAY '22 EVERY ~180 DAYS)  
Reference/Rationale: 13.6.9.3.1.1.1 Fire extinguishers shall shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification
- Item #: 5 APPLIANCE TO OUTLET  
Action Requested:  
Notes/Comments: REMOVE OUTLET SPLITTERS, PLUG APPLIANCES DIRECTLY TO PROPER OUTLET / 210.22  
Permissible Loads, Individual Branch Circuits.  
An individual branch circuit shall be permitted to supply any load for which it is rated, but in no case shall the total load exceed the branch-circuit ampere rating.  
Reference/Rationale: NFPA 70  
Print Date: October 21, 2022

INInspectionFindingsSingle 03/07/17