

**Town of Boxford  
Town Hall  
Boxford, MA**

**2017**

# HVAC Systems

**Prepared For:**

**Town of Boxford  
7 Spofford Road  
Boxford, MA 01921**

**Prepared By:**

**BLW Engineers, Inc.  
311 Great Road, P.O. Box 1551  
Littleton, MA 01460**

**May 5, 2017**

## **Section 23 00 00 – Heating, Ventilating and Air Conditioning (HVAC)**

### **GENERAL**

The current HVAC system for the existing 14,000 square foot Town Hall/Library consists of two gas fired boilers, hot water circulating pumps, blower coils located in the attic, remote air cooled condensing units, a hot water distribution piping system to hot water heating equipment, refrigerant piping system, ductwork distribution systems, exhaust fans, hot water unit heaters, hot water fin tube radiation and an automatic temperature control system.

The building has experienced significant heating and air conditioning related problems since it was renovated in 2004.

### **EXISTING CONDITIONS**

The building is provided with heating from two Burnham V910 hot water boilers rated for 1,329 MBH gross output each; lead/stand hot water circulating pumps rated for 186 gpm at 60' TDH each; hot water distribution piping system and automatic controls.

The following equipment provides heating, ventilating and air conditioning to the building:

<b>AREA</b>	<b>AHU/ACCU</b>	<b>CFM</b>	<b>OA CFM</b>	<b>COOLING</b>	<b>HW COIL</b>
1 <sup>ST</sup> Floor – East	AC-1/ACCU-1	2,225	645	72 MBH	183 MBH
1 <sup>ST</sup> Floor – West	AC-2/ACCU-2	1,750	645	72 MBH	183 MBH
1 <sup>ST</sup> /2 <sup>nd</sup> Floor – Lobby	AC-3/ACCU-3	1,650	750	72 MBH	183 MBH
1 <sup>ST</sup> Floor – Meeting	AC-4/ACCU-4	2,000	750	60 MBH*	183 MBH
2 <sup>ST</sup> Floor – East	AC-5/ACCU-5	2,920	615	90 MBH	275 MBH
2 <sup>ST</sup> Floor – Meeting	AC-6/ACCU-6	1,460	375	72 MBH	156 MBH
2 <sup>ST</sup> Floor – West	AC-7/ACCU-7	2,670	735	72 MBH	183 MBH
1 <sup>ST</sup> Floor – Tel/Data	AC-8/ACCU-8	555		24 MBH	

\*Scheduled for 72 MBH in original design drawings

Each of the above systems, except AC-8/ACCU-8 which is a ductless split system, consists of an air handling unit in the attic with refrigerant coil, remote air cooled condensing unit at grade, interconnecting refrigerant piping, a hot water heating coil located in the supply air ductwork interconnected to the hot water distribution piping system, supply/return duct distribution systems to air outlets in the respective zone, outdoor air ductwork interconnect to the ventilation air duct distribution system and a wall mounted thermostat for zone temperature control.

At some point in the last several years, humidifiers were added to each of the systems. These systems have been largely ineffective largely because they do not have adequate capacity to provide humidification for the excessive outdoor air flows provided in the design for building ventilation.

Ventilation air was designed to be provided by SF-1, SF-2, EF-3 and EF-4; all the fans are constant volume fans that are designed to provide the scheduled outdoor air volume to each air handling system.

Bathrooms are provided with toilet exhaust by inline exhaust fans, EF-1 and EF-2, located in the attic. At the time of the building inspection it was noted that the 2<sup>nd</sup> floor bathroom fan, EF-2, was not operational and did not extend to the outdoors (exhausted directly into the attic space). Over the years, the Town has tried adding space temperature sensors in additional spaces to help provide zone temperature control.

The building is also provided with fin tube radiation in the first level bathrooms, cabinet heaters in vestibules/stairs and hot water unit heaters in the storage, mechanical and attic areas of the building.

The following were noted or reported to be system operational issues:

1. Uneven heating/cooling within spaces within the same air conditioning/heating zone.
2. Ventilation air system overheats/overcools spaces and has been disabled.
3. Thermostat locations are not optimal increasing heating/cooling related issues.
4. System may have never been balanced and/or commissioned.

## **EVALUATION**

BLW Engineers performed heating, cooling and ventilation calculations for each zone of the building; the building is provided with significantly more cooling and ventilation capacity than required.

The major issues with the heating, ventilating and air conditioning system is as follows:

1. Zoning: The units in the attic are single zone systems that each serve spaces with different uses, occupancies and have different exposures to the outdoors. Even though there are eight units that provide eight heating/cooling zones within the building, the only spaces of each zone that will truly be satisfied is the zone with the zone thermostat controlling the respective system. The existing units do not have the capacity to add variable air volume terminal units and/or reheat coils due to the limited fan capacity and the DX cooling coil.
2. Thermostat Locations: Several thermostat locations are not ideal to provide heating/cooling to each zone; thermostats are sometimes located in interior spaces or other locations that do not represent the heating/cooling requirements of the respective zone.
3. Ventilation: The ventilation air flows to each zone are excessive and significantly exceed code requirements. SF-1, SF-2, EF-3 and EF-4 are constant volume fans that are designed to provide the scheduled outdoor air volume to each air handling system. Each system operates heating or cooling upon a call from the zone thermostat, when the thermostat is satisfied it circulates

return/outdoor air until another call for heating or cooling; since the outdoor air volume is a significantly percentage of the total air flow of each system, the mixed air temperatures are very low in winter (40s) and very high in summer (85+) leading to very uneven air temperature distribution, humidification/dehumidification issues and difficulty in recovery to space temperature setpoints.

4. 2<sup>nd</sup> Floor Toilet Exhaust: the 2<sup>nd</sup> floor bathroom fan, EF-2, was not operational and did not extend to the outdoors (exhausted directly into the attic space).
5. Air Conditioning: The units were sized for the high mixed air temperatures due to the high percentage of outdoor air (up to 45% of total air flow); unfortunately, DX cooling systems do not operate well for outdoor air percentages exceeding 30 percent.
6. Balancing/Commissioning: It is not clear if the systems were ever properly balanced and/or commissioned which could be significantly impacting the operation of the system.

## **RECOMMENDATIONS**

### **Option 1 – Existing System Upgrades**

1. Relocate thermostats into more appropriate locations; add thermostats for averaging system operation.
2. Add controls for demand control ventilation and discharge air temperature control.
3. Modify supply ventilation system (F-1, F-2, EF-3 and EF-4) including variable speed controls to provide code required ventilation and/or demand control ventilation to the respective zones.
4. Repair 2<sup>nd</sup> floor toilet exhaust fan and extend to the outdoors.
5. Balance existing system to calculated airflows for heating and cooling.
6. Commission systems for proper sequence of operation.

**Note:** Option 1 would help alleviate some of the issues with the current system operation but will not entirely correct them; each system will still be a single zone system trying to satisfied multiple spaces within the zone.

The estimated construction costs for Option 1 is \$ **123,654.00**.

### **Option 2 – Existing System Replacement**

1. Replace existing air cooled condensing units, refrigerant piping system, attic air handling units with new air cooled chiller, chilled water pumping/piping system, variable air volume terminal units for each zone within the building, variable air volume air handling units with hot/chilled water coils in the attic, ductwork modifications and a new system of automatic temperature controls.

2. Add controls for demand control ventilation and discharge air temperature control.
3. Modify supply ventilation system (F-1, F-2, EF-3 and EF-4) including variable speed controls to provide code required ventilation and/or demand control ventilation to the respective zones.
4. Repair 2<sup>nd</sup> floor toilet exhaust fan and extend to the outdoors.
5. Balance existing system to calculated airflows for heating and cooling.
6. Commission systems for proper sequence of operation.

**Note:** Option 2 would be fairly invasive to the building but would be the ideal solution for the solving the noted issues; probably 3-4 weeks disruption to the entire building for the installation of replacement equipment in the attic and then 1-2 weeks of interruption of the heating or cooling for each zone or could be performed with less disruption during mild spring or fall weather.

The estimated construction costs for Option 2 is **\$ 558,687.00**.

## **Estimated Construction Costs**







## **Calculations**

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

Project phase:	Preliminary	Project:	Boxford	Date	00.00.00
Trade Specification Section:	15500	Project No.:	17076		
By:	Checked By:				

Design Conditions:					
Location	Temps.	Summer	Winter	IMC 2012, IECC 2012	
-	Indoor	(*F-Db/F-Wb) 75	63	70 °F	
	Outdoor	(*F-Db/F-Wb) 88	74	9 °F	

### I. Envelope Assumptions

Component	Value	
wall ht	12.00	ft
window ht	5.00	ft
ceiling ht	12.00	ft
lighting	2.00	W/ft2
activity lvl	255.00	BTU/hr
window shading	0.83	SC

Component	R-value	U-value	
wall	13.00	0.08	BTU/hr ft2 F
window	2.50	0.55	BTU/hr ft2 F
skylight	2.50	0.40	BTU/hr ft2 F
roof	20.00	0.05	BTU/hr ft2 F
door	1.25	0.80	BTU/hr ft2 F
slab	10.00	0.10	BTU/hr ft2 F
floor	30.00	0.03	BTU/hr ft2 F

### Equipment Assumptions

DeR - Derated Heating requirement (60% derate at 0F)

Total is based on cfm from sensible calc and OA req

Total Heating based on MAT being heated to 90

### II. HVAC Loads

w/o treating air

w/o treating air

Space	OA Req	Sens Clg	Total Clg	Clg CFM	-	Min Htg	Total Htg	Htg CFM	Area	-	btuh/sf	sf/ton	Occ.	MAT Clg DB	MAT Clg WB	LAT Clg DB	LAT Clg WB	MAT Htg	LAT Htg	DeR
100 LOBBY	4	4,754	6,495	220	-	2,616	3,368	220	70	-	48	129	0	78	65	56	55	69	83	4.36
101A TAX DROP	2	1,709	2,354	79	-	1,566	1,875	79	35	-	54	178	0	78	65	56	55	68	90	2.61
101B MAIL DROP	1	1,902	2,591	88	-	1,580	1,865	88	24	-	78	111	0	78	65	56	55	69	89	2.63
102 STAIR #1	5	1,055	368	7	-	0	328	7	79	-	4	2573	0	85	71	56	55	30	72	0
101 CORRIDOR	40	10,097	14,787	467	-	8,683	12,325	467	666	-	19	540	0	79	65	56	55	65	89	14.5
105 STAIR #2	7	585	1,006	27	-	2,657	3,166	27	114	-	28	1360	0	81	67	56	55	55	163	4.43
110 MACHINE ROOM	2	322	510	15	-	0	194	15	41	-	5	965	0	80	66	56	55	60	72	0
107 PANTRY	80	2,852	6,505	132	-	0	5,533	132	113	-	49	208	8	84	70	56	55	33	72	0
109 A/V CLOSET	5	205	449	9	-	0	364	9	87	-	4	2324	0	84	70	56	55	36	72	0
108 CHAIRS	9	172	511	8	-	0	541	8	73	-	7	1715	0	88	74	56	55	9	72	0
111 STAIR #3	7	589	1,012	27	-	2,663	3,177	27	115	-	28	1364	0	81	67	56	55	55	163	4.44
112 COPY	2	322	510	15	-	0	194	15	41	-	5	965	0	80	66	56	55	60	72	0
106 LARGE MTG. RM	261	24,940	41,833	1,155	-	19,847	39,537	1,155	842	-	47	242	42	80	67	56	55	56	88	33.1
114 CLERK WAITING	44	3,748	6,446	174	-	3,040	6,313	174	400	-	16	745	4	81	67	56	55	55	88	5.07
115 CONF. 1	43	2,619	4,910	121	-	0	3,080	121	138	-	22	337	7	82	68	56	55	48	72	0
16 CUST./EQUIP STORAGE	16	2,488	3,857	115	-	5,608	6,940	115	274	-	25	852	0	79	66	56	55	61	117	9.35
117 MECHANICAL	13	3,611	5,248	167	-	2,959	4,178	167	217	-	19	496	0	79	65	56	55	65	88	4.93
118 ELECTRICAL	3	1,039	1,490	48	-	1,599	1,908	48	52	-	37	419	0	79	65	56	55	66	103	2.86
118A EMERG. ELEC.	1	368	532	17	-	516	636	17	21	-	30	473	0	79	65	56	55	65	100	0.66
119 CLERK	35	15,878	22,350	735	-	11,250	15,122	735	408	-	37	219	2	78	65	56	55	67	86	18.7
120 VAULT	10	1,108	1,796	51	-	2,021	2,772	51	162	-	17	1082	0	80	66	56	55	58	108	3.37
121 WOMEN	24	3,115	4,930	144	-	2,761	4,630	144	144	-	32	351	3	80	66	56	55	60	90	4.6
122 JAN	2	53	126	2	-	0	112	2	27	-	4	2573	0	85	71	56	55	30	72	0
123 MEN	24	2,872	4,607	133	-	2,774	4,622	133	145	-	32	378	3	80	66	56	55	59	91	4.62
25 OPEN LIBRARY AREA	254	22,463	38,324	1,040	-	19,050	38,062	1,040	1,497	-	25	469	15	80	67	56	55	55	89	31.8
125 TAX COLLECTOR	40	11,463	16,608	531	-	9,261	13,028	531	468	-	28	338	2	79	65	56	55	65	88	15.4
126 COLLECTOR OFFICE	10	3,519	5,037	163	-	3,335	4,364	163	121	-	36	288	1	79	65	56	55	66	91	5.56
201 CORRIDOR	33	9,595	13,884	444	-	10,097	13,215	444	546	-	24	472	0	79	65	56	55	66	93	16.8
202 CO	19	19,343	26,472	896	-	13,544	16,700	896	309	-	54	140	0	78	65	56	55	69	86	22.6
203 JAN	2	159	271	7	-	166	300	7	30	-	10	1328	0	80	67	56	55	55	93	0.28
204 MEN	8	587	1,034	27	-	229	791	27	44	-	18	511	1	81	67	56	55	53	80	0.38
206 STAIR #5	5	476	812	22	-	496	899	22	90	-	10	1330	0	80	67	56	55	55	93	0.83
207 DEAD FILE STORAGE	5	790	1,221	37	-	1,698	2,113	37	85	-	25	835	0	79	66	56	55	61	115	2.83
208 SMALL MTG. ROOM	128	10,516	18,248	487	-	7,182	16,689	487	414	-	40	272	21	81	67	56	55	54	86	12
208.1 MECH. CLOSET	3	526	794	24	-	260	498	24	47	-	11	711	0	79	66	56	55	63	82	0.43
209 WOMEN	8	637	1,112	29	-	276	867	29	50	-	17	539	1	81	67	56	55	53	81	0.46
210 STAIR #1	7	767	1,252	36	-	1,421	1,956	36	116	-	17	1112	0	80	66	56	55	58	109	2.37
212 DEAD FILE STORAGE	5	792	1,223	37	-	1,703	2,118	37	85	-	25	834	0	79	66	56	55	62	115	2.84
213 STAIR #3	6	498	849	23	-	520	941	23	94	-	10	1328	0	80	67	56	55	55	93	0.87
214 ADMIN WAITING	41	4,657	7,556	216	-	4,920	8,089	216	373	-	22	592	4	80	66	56	55	58	93	8.2
215 FINANCE OFFICE	29	6,772	9,988	314	-	7,346	9,932	314	341	-	29	410	2	79	65	56	55	64	94	12.2
216 ACCOUNTANT	13	2,472	3,735	114	-	3,121	4,247	114	139	-	31	447	1	79	66	56	55	63	97	5.2
217 FINANCE DIRECTOR	13	3,882	5,617	180	-	4,463	5,722	180	137	-	42	293	1	79	65	56	55	66	95	7.44
218 MAIL/COPY	21	5,527	8,063	256	-	4,613	6,543	256	182	-	36	271	2	79	65	56	55	65	89	7.69
219 DEAD FILE STORAGE	5	471	804	22	-	492	891	22	89	-	10	1328	0	80	67	56	55	55	93	0.82
220 SELECTMEN	24	10,119	14,312	468	-	8,279	10,887	468	285	-	38	239	1	79	65	56	55	67	88	13.8
ASSISTANT ADMINISTRATOR	16	4,798	6,916	222	-	4,574	6,079	222	183	-	33	318	1	79	65	56	55	66	91	7.62
22 TOWN ADMINISTRATOR	24	10,009	14,172	463	-	8,439	11,053	463	288	-	38	244	1	79	65	56	55	67	89	14.1
223 REGULATORY WAITING	39	4,378	7,115	203	-	4,688	7,691	203	354	-	22	597	4	80	66	56	55	58	93	7.81
224 INSPECTORIAL DEPT.	24	10,100	14,273	468	-	8,288	10,866	468	280	-	39	235	1	79	65	56	55	67	88	13.8
225 BUILDING INSPECTOR	11	7,022	9,742	325	-	5,219	6,638	325	128	-	52	158	1	78	65	56	55	68	87	8.7
226 ZBA	13	2,865	4,258	133	-	3,048	4,208	133	156	-	27	440	1	79	66	56	55	64	93	5.08
227 HEALTH	21	5,143	7,556	238	-	5,355	7,258	238	248	-	29	394	1	79	65	56	55	65	93	8.92
228 HEALTH DIRECTOR	11	3,703	5,300	171	-	3,994	5,075	171	127	-	40	288	1	79	65	56	55	66	94	6.66
229 CONS COM/PLANNING	30	5,029	7,695	233	-	5,631	8,116	233	354	-	23	552	2	79	66	56	55	62	94	9.39
CONSERVATION DIRECTOR	9	3,337	4,761	155	-	3,935	4,879	155	109	-	45	275	1	79	65	56	55	66	96	6.56
CONSERVATION ASSISTANT	10	3,114	4,487	144	-	3,525	4,497	144	118	-	38	316	1	79	65	56	55	66	95	5.88
232 PLANNER	9	2,430	3,550	112	-	2,742	3,601	112	110	-	33	372	1	79	65	56	55	65	95	4.57
~	0	0	0	0	-	0	#DIV/0!	0	0	-	0	0	0	0	0	56	55	9	#DIV/0!	0
~	0	0	0	0	-	0	#DIV/0!	0	0	-	0	0	0	0	0	56	55	9	#DIV/0!	0
~	0	0	0	0	-	0	#DIV/0!	0	0	-	0	0	0	0	0	56	55	9	#DIV/0!	0
~	0	0	0	0	-	0	#DIV/0!	0	0	-	0	0	0	0	0	56	55	9	#DIV/0!	0

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

Project phase: Preliminary	Project: <b>Boxford</b>	Sheet: 1 of 1
Trade Specification Section: 15500	100 LOBBY	Date
By: _____	Checked By: _____	Project No.: 17076
Design Conditions:		00.00.00

Location	Temps.	Summer	Winter
-	Indoor	(°F-Db/°F-Wb) 75	63 70 °F IMC 2012, IECC 2012
	Outdoor	(°F-Db/°F-Wb) 88	74 9 °F

### I. Outdoor Air Requirement

Area	Method	70	ft2	A	+	Rp	P													
Ventilation	per Person	0.06	x	70		5	x	0												4.2 CFM
	per ACH	2.00	x	0	ft2	x	12.00	ft	/	60	min/hr	=								0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F		=						0	Btu/hr
	S	11	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F		=						308	Btu/hr
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F		=						0	Btu/hr
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F		=						0	Btu/hr
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F		=						0	Btu/hr
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F		=						0	Btu/hr
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F		=						0	Btu/hr
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F		=						0	Btu/hr
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=				0	Btu/hr
	S	6	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=				3,135	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=				0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=				0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=				0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=				0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=				0	Btu/hr
SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=				0	Btu/hr	
Glass		6	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F		=					300	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F		=					0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F				=						0	Btu/hr	
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F				=						0	Btu/hr	
Lighting/Power		70	ft2	x	1.30	W/ft2	x	3.412	Btu/h/Watt				=						310	Btu/hr	
People		0	People	x	255	Btu/hr	x	1	Diversity				=						0	Btu/hr	
Infiltration		70	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=			80	Btu/hr	
<b>Sensible(w/o treating air)</b>																					
RSH																			=	4,134	Btu/hr
Safety Factor (15%)																			=	620	Btu/hr
ERSH																			=	4,754	Btu/hr
Airflow (20F delta T)																			=	220	CFM

### III. Heating Load

Walls					87.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F		=						408	Btu/hr
Glass					39.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F		=						1,308	Btu/hr
Skylight					0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F		=						0	Btu/hr
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F		=						0	Btu/hr
Roof		0	ft2	x	61	F	x	0.05	Btu/hr ft2 F				=						0	Btu/hr	
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F				=						0	Btu/hr	
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F				=						0	Btu/hr	
Infiltration		70	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=			376	Btu/hr	
(not treating air)																					
Heating																			=	2,093	Btu/hr
Safety Factor (25%)																			=	523	Btu/hr
MIN HEATING																			=	2,616	Btu/hr

### IV. Furnace Specifications

AHU	Enthalpy-In	29.73	Btu/lb	@	78.19	F DB	,	64.78	F WB	,	2	% OA										
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB													
	Cooling Cap	220	CFM	x	6.56	BTU/lb	x	4.5													6,495	Btu/hr
<b>Tons A/C</b>																			=	0.5	Tons	
<b>H2O (10F delta T)</b>																			=	1	GPM	
<b>H2O (20F delta T)</b>																			=	129	ft2/Ton	
	Mix Air T-In	69	F	@	2	% OA																
	Heat Air T-Out	83	F																			
	Heating Cap	220	CFM	x	14	F	x	1.08													3,368	Btu/hr
<b>H2O (20F delta T)</b>																			=	0	GPM	
<b>H2O (20F delta T)</b>																			=	48	Btu/ft2	

# BLW

## BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

### HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	101A TAX DROP	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
<b>Design Conditions:</b>		00.00.00
<b>Location</b>	<b>Temps.</b>	
-	<b>Indoor</b> (°F-Db/°F-Wb) 75	63
	<b>Outdoor</b> (°F-Db/°F-Wb) 88	74
	<b>Winter</b> 70 °F	IMC 2012, IECC 2012
		9 °F

#### I. Outdoor Air Requirement

Area	35	ft2													
Method	Ra		A				Rp		P						
Ventilation per Person	0.06	x	35		+		5	x	0						= 2.1 CFM
per ACH	2.00	x	0	ft2	x	12.00	ft	/	60	min/hr					= 0 CFM

#### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	7	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	248	Btu/hr	
	E	7	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	207	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	2	ft	x	7	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	784	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		2	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	75	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	0	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		35	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt			=	131	Btu/hr		
People		0	People	x	255	Btu/hr	x	1	Diversity			=	0	Btu/hr		
Infiltration		35	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	40	Btu/hr

<b>RSH</b>	=	1,486	Btu/hr
<b>Safety Factor (15%)</b>	=	223	Btu/hr
<b>ERSH</b>	=	1,709	Btu/hr
<b>Airflow (20F delta T)</b>	=	79	CFM

*Sensible(w/o treating air)*

#### III. Heating Load

Walls	157.17	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	737	Btu/hr				
Glass	9.75	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	327	Btu/hr				
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr				
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr			
Roof	0	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	0	Btu/hr				
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr				
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr				
Infiltration	35	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	188	Btu/hr

<b>Heating</b>	=	1,253	Btu/hr
<b>Safety Factor (25%)</b>	=	313	Btu/hr
<b>MIN HEATING</b>	=	1,566	Btu/hr

(not treating air)

#### IV. Furnace Specifications

AHU	Enthalpy-In	29.79	Btu/lb	@	78.27	F DB	,	64.85	F WB	,	3	% OA			
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB						
	Cooling Cap	79	CFM	x	6.61	BTU/lb	x	4.5					=	2,354	Btu/hr
													=	0.2	Tons
													=	0	GPM
													=	178	ft2/Ton
	Mix Air T-In	68	F	@	3	% OA									
	Heat Air T-Out	90	F												
	Heating Cap	79	CFM	x	22	F	x	1.08					=	1,875	Btu/hr

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	101B MAIL DROP	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P	0	=	1.44 CFM
Ventilation	per Person	0.06	x	24	+	5	x	0	=
	per ACH	2.00 ACH	x	0	ft2	x	12.00	ft	/
								60	min/hr
									=
									0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	7	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	257	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	7	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	277	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	2	ft	x	7	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	914	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		2	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	88	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F	=	0	Btu/hr				
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F	=	0	Btu/hr				
Lighting/Power		24	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt	=	90	Btu/hr				
People		0	People	x	255	Btu/hr	x	1	Diversity	=	0	Btu/hr				
Infiltration		24	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	27	Btu/hr
<b>RSH</b>														=	1,654	Btu/hr
<b>Safety Factor (15%)</b>														=	248	Btu/hr
<b>ERSH</b>														=	1,902	Btu/hr
<b>Airflow (20F delta T)</b>														=	88	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	160.59	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	754	Btu/hr				
Glass	11.38	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	382	Btu/hr				
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr				
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr			
Roof	0	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	0	Btu/hr				
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr				
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr				
Infiltration	24	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	129	Btu/hr
<b>Heating</b>											=	1,264	Btu/hr		
<b>Safety Factor (25%)</b>											=	316	Btu/hr		
<b>MIN HEATING</b>											=	1,580	Btu/hr		

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	29.71	Btu/lb	@	78.16	F DB	,	64.75	F WB	,	2	% OA	=	2,591	Btu/hr
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB				=		
	Cooling Cap	88	CFM	x	6.54	BTU/lb	x	4.5					=		
													=	0.2	Tons
													=	1	GPM
													=	111	ft2/Ton
	Mix Air T-In	69	F	@	2	% OA							=		
	Heat Air T-Out	89	F										=		
	Heating Cap	88	CFM	x	20	F	x	1.08					=	1,865	Btu/hr



# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	101 CORRIDOR	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b> (°F-Db/°F-Wb) 75	63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b> (°F-Db/°F-Wb) 88	74	9 °F

### I. Outdoor Air Requirement

Area	666	ft2	A	Rp	P				
Ventilation Method	Ra	x	A	x	P	=			
per Person	0.06	x	666		5	x	0	=	39.96 CFM
per ACH	2.00 ACH	x	0	ft2	x	12.00	ft	/	60 min/hr = 0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	S	24	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	788	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	11	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	5,559	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		11	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	533	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F					=	0	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Lighting/Power	666	ft2	x	0.50	W/ft2	x	3.412	Btu/h/Watt						=	1,136	Btu/hr		
People	0	People	x	255	Btu/hr	x	1	Diversity						=	0	Btu/hr		
Infiltration	666	ft2	x	12.00	ft	x	13	F	x	1.08	x	0.4 ACH	x	0.017	min/hr	=	763	Btu/hr

<b>RSH</b>	=	8,780	Btu/hr
<b>Safety Factor (15%)</b>	=	1,317	Btu/hr
<b>ERSH</b>	=	10,097	Btu/hr
<b>Airflow (20F delta T)</b>	=	467	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls					222.80	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	1,045	Btu/hr	
Glass					69.16	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	2,320	Btu/hr	
Skylight					0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Door	0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr		
Roof	0	ft2	x	61	F	x	0.05	Btu/hr ft2 F						=	0	Btu/hr		
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F						=	0	Btu/hr		
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F						=	0	Btu/hr		
Infiltration	666	ft2	x	12.00	ft	x	61	F	x	1.08	x	0.4 ACH	x	0.017	min/hr	=	3,580	Btu/hr

<b>Heating</b>	=	6,946	Btu/hr
<b>Safety Factor (25%)</b>	=	1,737	Btu/hr
<b>MIN HEATING</b>	=	8,683	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.20	Btu/lb	@	78.85	F DB	,	65.40	F WB	,	9	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	467	CFM	x	7.03	BTU/lb	x	4.5						=	14,787	Btu/hr
														=	1.2	Tons
														=	3	GPM
														=	540	ft2/Ton
	Mix Air T-In	65	F	@	9	% OA										
	Heat Air T-Out	89	F													
	Heating Cap	467	CFM	x	24	F	x	1.08						=	12,325	Btu/hr

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	105 STAIR #2	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b> (°F-Db/°F-Wb) 75	63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b> (°F-Db/°F-Wb) 88	74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P						
Ventilation per Person per ACH		0.06	x	114	+	5	x	0	=	6.84 CFM		
		2.00 ACH	x	0	ft2	x	12.00	ft	/	60	min/hr	=
												0 CFM

### II. Sensible Cooling Load

Walls	N	9	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	184	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	0	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		114	ft2	x	0.50	W/ft2	x	3.412	Btu/h/Watt			=	194	Btu/hr		
People		0	People	x	255	Btu/hr	x	1	Diversity			=	0	Btu/hr		
Infiltration		114	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	131	Btu/hr

<b>RSH</b>	=	509	Btu/hr
<b>Safety Factor (15%)</b>	=	76	Btu/hr
<b>ERSH</b>	=	585	Btu/hr
<b>Airflow (20F delta T)</b>	=	27	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	103.92	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	488	Btu/hr		
Glass	0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr		
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr		
Door	3	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	1,025	Btu/hr	
Roof	0	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	0	Btu/hr		
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr		
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr		
Infiltration	114	ft2	x	12.00	ft	x	61	F x 1.08	x 0.4 ACH x 0.017	min/hr	=	613	Btu/hr

<b>Heating</b>	=	2,125	Btu/hr
<b>Safety Factor (25%)</b>	=	531	Btu/hr
<b>MIN HEATING</b>	=	2,657	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	31.42	Btu/lb	@	80.52	F DB	,	66.97	F WB	,	25	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	27	CFM	x	8.25	BTU/lb	x	4.5					=	1,006	Btu/hr	
													=	0.1	Tons	
													=	0	GPM	
													=	1360	ft2/Ton	
	Mix Air T-In	55	F	@	25	% OA										
	Heat Air T-Out	163	F													
	Heating Cap	27	CFM	x	108	F	x	1.08					=	3,166	Btu/hr	







# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	109 A/V CLOSET	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P						
Ventilation	per Person	0.06	x	87	+	5	x	0	=	5.22	CFM	
	per ACH	2.00	ACH	x	0	ft2	x	12.00	ft	/	60	min/hr
									=		0	CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr	
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr	
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr	
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr	
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr	
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr	
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr	
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr	
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr		
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr		
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	0	Btu/hr			
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr			
Lighting/Power		87	ft2	x	0.60	W/ft2	x	3.412	Btu/h/Watt			=	178	Btu/hr			
People		0	People	x	255	Btu/hr	x	1	Diversity			=	0	Btu/hr			
Infiltration		0	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x 0.017	min/hr	=	0	Btu/hr

<b>RSH</b>	=	178	Btu/hr
<b>Safety Factor (15%)</b>	=	27	Btu/hr
<b>ERSH</b>	=	205	Btu/hr
<b>Airflow (20F delta T)</b>	=	9	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	0.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	0	Btu/hr					
Glass	0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr					
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr					
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr				
Roof	0	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	0	Btu/hr					
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr					
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr					
Infiltration	0	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x 0.017	min/hr	=	0	Btu/hr

<b>Heating</b>	=	0	Btu/hr
<b>Safety Factor (25%)</b>	=	0	Btu/hr
<b>MIN HEATING</b>	=	0	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	33.70	Btu/lb	@	83.50	F DB	,	69.77	F WB	,	55	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	9	CFM	x	10.53	BTU/lb	x	4.5					=	449	Btu/hr	
													=	0.0	Tons	
													=	0	GPM	
													=	2324	ft2/Ton	
	Mix Air T-In	36	F	@	55	% OA										
	Heat Air T-Out	72	F													
	Heating Cap	9	CFM	x	36	F	x	1.08					=	364	Btu/hr	



# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	111 STAIR #3	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b> (°F-Db/°F-Wb) 75	63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b> (°F-Db/°F-Wb) 88	74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P						
Ventilation	per Person	0.06	x	115	+	5	x	0	=	6.9 CFM		
	per ACH	2.00 ACH	x	0	ft2	x	12.00	ft	/	60	min/hr	=
												0 CFM

### II. Sensible Cooling Load

Walls	N	9	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	184	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	0	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		115	ft2	x	0.50	W/ft2	x	3.412	Btu/h/Watt			=	196	Btu/hr		
People		0	People	x	255	Btu/hr	x	1	Diversity			=	0	Btu/hr		
Infiltration		115	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	132	Btu/hr

<b>RSH</b>	=	512	Btu/hr
<b>Safety Factor (15%)</b>	=	77	Btu/hr
<b>ERSH</b>	=	589	Btu/hr
<b>Airflow (20F delta T)</b>	=	27	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls					103.92	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	488	Btu/hr	
Glass					0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight					0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Door		3	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F	=	1,025	Btu/hr	
Roof		0	ft2	x	61	F	x	0.05	Btu/hr ft2 F			=	0	Btu/hr		
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F			=	0	Btu/hr		
Infiltration		115	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	618	Btu/hr

<b>Heating</b>	=	2,131	Btu/hr
<b>Safety Factor (25%)</b>	=	533	Btu/hr
<b>MIN HEATING</b>	=	2,663	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	31.43	Btu/lb	@	80.53	F DB	,	66.98	F WB	,	25	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	27	CFM	x	8.25	BTU/lb	x	4.5					=	1,012	Btu/hr	
													=	0.1	Tons	
													=	0	GPM	
													=	1364	ft2/Ton	
	Mix Air T-In	55	F	@	25	% OA										
	Heat Air T-Out	163	F													
	Heating Cap	27	CFM	x	108	F	x	1.08					=	3,177	Btu/hr	





# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

Project phase: Preliminary	Project: <b>Boxford</b>	Sheet: 1 of 1
Trade Specification Section: 15500	114 CLERK WAITING	Date
By: _____	Project No.: 17076	00.00.00

Design Conditions:		
Location	Temps. Summer	Winter
-	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	Outdoor (°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	400	ft2	Ra	A	Rp	P	=			
Ventilation	per Person	0.06	x	400	+	5	x	4	=	44 CFM	
	per ACH	2.00	x	0	ft2	x	12.00	ft	/	60	
										min/hr	
										=	0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	E	5	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	143	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	0	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		400	ft2	x	1.20	W/ft2	x	3.412	Btu/Watt			=	1,638	Btu/hr		
People		4	People	x	255	Btu/hr	x	1	Diversity			=	1,020	Btu/hr		
Infiltration		400	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	458	Btu/hr

<b>RSH</b>	=	3,259	Btu/hr
<b>Safety Factor (15%)</b>	=	489	Btu/hr
<b>ERSH</b>	=	3,748	Btu/hr
<b>Airflow (20F delta T)</b>	=	174	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	60.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	282	Btu/hr				
Glass	0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr				
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr				
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr			
Roof	0	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	0	Btu/hr				
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr				
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr				
Infiltration	400	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	2,150	Btu/hr

<b>Heating</b>	=	2,432	Btu/hr
<b>Safety Factor (25%)</b>	=	608	Btu/hr
<b>MIN HEATING</b>	=	3,040	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	31.43	Btu/lb	@	80.54	F DB	,	66.98	F WB	,	25	% OA			
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB						
	Cooling Cap	174	CFM	x	8.25	BTU/lb	x	4.5					=	6,446	Btu/hr
													=	0.5	Tons
													=	1	GPM
													=	745	ft2/Ton
	Mix Air T-In	55	F	@	25	% OA									
	Heat Air T-Out	88	F												
	Heating Cap	174	CFM	x	34	F	x	1.08					=	6,313	Btu/hr



# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

Project phase: Preliminary	Project: <b>Boxford</b>	Sheet: 1 of 1
Trade Specification Section: 15500	115 CONF. 1	Date
By: _____	Project No.: <b>17076</b>	00.00.00

<b>Design Conditions:</b>			
Location	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	138	ft2	A	138	+	12.00	ft	5	x	7	60	min/hr	=	42.78 CFM
Ventilation	per Person	0.06	x	A	138	+	12.00	ft	5	x	7	60	min/hr	=	0 CFM
	per ACH	2.00	x	A	138	+	12.00	ft	5	x	7	60	min/hr	=	0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F		=	0	Btu/hr		
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F		=	0	Btu/hr		
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F				=	0	Btu/hr			
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F				=	0	Btu/hr			
Lighting/Power		138	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt				=	518	Btu/hr			
People		7	People	x	255	Btu/hr	x	1	Diversity				=	1,760	Btu/hr			
Infiltration		0	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	0	Btu/hr
<b>RSH</b>														=	2,277	Btu/hr		
<b>Safety Factor (15%)</b>														=	342	Btu/hr		
<b>ERSH</b>														=	2,619	Btu/hr		
<b>Airflow (20F delta T)</b>														=	121	CFM		

*Sensible(w/o treating air)*

### III. Heating Load

Walls					0.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
Glass					0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F		=	0	Btu/hr		
Skylight					0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F		=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F		=	0	Btu/hr		
Roof		0	ft2	x	61	F	x	0.05	Btu/hr ft2 F				=	0	Btu/hr			
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F				=	0	Btu/hr			
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F				=	0	Btu/hr			
Infiltration		0	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	0	Btu/hr
<b>Heating</b>														=	0	Btu/hr		
<b>Safety Factor (25%)</b>														=	0	Btu/hr		
<b>MIN HEATING</b>														=	0	Btu/hr		

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	32.17	Btu/lb	@	81.53	F DB	,	67.92	F WB	,	35	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	121	CFM	x	9.00	BTU/lb	x	4.5					=	4,910	Btu/hr	
													=	0.4	Tons	
													=	1	GPM	
													=	337	ft2/Ton	
	Mix Air T-In	48	F	@	35	% OA										
	Heat Air T-Out	72	F													
	Heating Cap	121	CFM	x	24	F	x	1.08					=	3,080	Btu/hr	



# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	117 MECHANICAL	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	217	ft2	A	Rp	P				
Ventilation	per Person	0.06	x	217	+	5	x	0	=	13.02 CFM
	per ACH	2.00	x	0	ft2	x	12.00	ft	/	60
										min/hr
										=
										0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	13	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	441	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	3	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	845	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		3	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	125	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F					=	0	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Lighting/Power		217	ft2	x	2.00	W/ft2	x	3.412	Btu/h/Watt					=	1,481	Btu/hr		
People		0	People	x	255	Btu/hr	x	1	Diversity					=	0	Btu/hr		
Infiltration		217	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	249	Btu/hr

<b>RSH</b>				=	3,140	Btu/hr
<b>Safety Factor (15%)</b>				=	471	Btu/hr
<b>ERSH</b>				=	3,611	Btu/hr
<b>Airflow (20F delta T)</b>				=	167	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls					139.75	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	656	Btu/hr	
Glass					16.25	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	545	Btu/hr	
Skylight					0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	61	F	x	0.05	Btu/hr ft2 F					=	0	Btu/hr		
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F					=	0	Btu/hr		
Infiltration		217	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	1,167	Btu/hr

<b>Heating</b>				=	2,367	Btu/hr
<b>Safety Factor (25%)</b>				=	592	Btu/hr
<b>MIN HEATING</b>				=	2,959	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.15	Btu/lb	@	78.78	F DB	,	65.33	F WB	,	8	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	167	CFM	x	6.98	BTU/lb	x	4.5						=	5,248	Btu/hr
														=	0.4	Tons
														=	1	GPM
														=	496	ft2/Ton
	Mix Air T-In	65	F	@	8	% OA										
	Heat Air T-Out	88	F													
	Heating Cap	167	CFM	x	23	F	x	1.08						=	4,178	Btu/hr



# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	118A EMERG. ELEC.	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	21	ft2	x	A	Rp	P	0	=	1.26 CFM		
Ventilation	per Person	0.06	x	21	ft2	x	12.00	ft	/	60	min/hr	=	0 CFM
	per ACH	2.00	x	0	ft2	x	12.00	ft	/	60	min/hr	=	0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	E	5	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	153	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	0	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		21	ft2	x	2.00	W/ft2	x	3.412	Btu/h/Watt			=	143	Btu/hr		
People		0	People	x	255	Btu/hr	x	1	Diversity			=	0	Btu/hr		
Infiltration		21	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	24	Btu/hr

<b>RSH</b>	=	320	Btu/hr
<b>Safety Factor (15%)</b>	=	48	Btu/hr
<b>ERSH</b>	=	368	Btu/hr
<b>Airflow (20F delta T)</b>	=	17	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	63.96	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	300	Btu/hr		
Glass	0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr		
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr		
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr	
Roof	0	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	0	Btu/hr		
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr		
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr		
Infiltration	21	ft2	x	12.00	ft	x	61	F x 1.08	x 0.4 ACH x 0.017	min/hr	=	113	Btu/hr

<b>Heating</b>	=	413	Btu/hr
<b>Safety Factor (25%)</b>	=	103	Btu/hr
<b>MIN HEATING</b>	=	516	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.12	Btu/lb	@	78.74	F DB	,	65.30	F WB	,	7	% OA	=	532	Btu/hr
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB				=	0	Tons
	Cooling Cap	17	CFM	x	6.95	BTU/lb	x	4.5					=	0	GPM
													=	473	ft2/Ton
	Mix Air T-In	65	F	@	7	% OA							=		
	Heat Air T-Out	100	F										=		
	Heating Cap	17	CFM	x	35	F	x	1.08					=	636	Btu/hr



# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	120 VAULT	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P				
Ventilation	per Person	0.06	x	162	+	5	x	0	=	9.72 CFM
	per ACH	2.00	x	0	ft2	x	12.00	ft	/	60
									=	0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	13	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	501	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	7	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F					=	0	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Lighting/Power		162	ft2	x	0.50	W/ft2	x	3.412	Btu/h/Watt					=	276	Btu/hr		
People		0	People	x	255	Btu/hr	x	1	Diversity					=	0	Btu/hr		
Infiltration		162	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	186	Btu/hr

<b>RSH</b>	=	963	Btu/hr
<b>Safety Factor (15%)</b>	=	145	Btu/hr
<b>ERSH</b>	=	1,108	Btu/hr
<b>Airflow (20F delta T)</b>	=	51	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls					159.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	746	Btu/hr	
Glass					0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	0	Btu/hr	
Skylight					0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr	
Roof		0	ft2	x	61	F	x	0.05	Btu/hr ft2 F					=	0	Btu/hr		
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F					=	0	Btu/hr		
Infiltration		162	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	871	Btu/hr

<b>Heating</b>	=	1,617	Btu/hr
<b>Safety Factor (25%)</b>	=	404	Btu/hr
<b>MIN HEATING</b>	=	2,021	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.96	Btu/lb	@	79.89	F DB	,	66.38	F WB	,	19	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	51	CFM	x	7.78	BTU/lb	x	4.5						=	1,796	Btu/hr
														=	0.1	Tons
														=	0	GPM
														=	1082	ft2/Ton
	Mix Air T-In	58	F	@	19	% OA										
	Heat Air T-Out	108	F													
	Heating Cap	51	CFM	x	50	F	x	1.08						=	2,772	Btu/hr

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	121 WOMEN	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	144	ft2	A	Rp	P	3	=	23.64 CFM
Ventilation per Person		0.06	x	144		5	x	3	=	23.64 CFM
per ACH		2.00 ACH	x	0	ft2	x	12.00	ft	/	60
										min/hr
									=	0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	10	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	439	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	11	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	376	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	3	ft	x	4	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	455	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		3	ft	x	3.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	67	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	0	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		144	ft2	x	0.90	W/ft2	x	3.412	Btu/h/Watt			=	442	Btu/hr		
People		3	People	x	255	Btu/hr	x	1	Diversity			=	765	Btu/hr		
Infiltration		144	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	165	Btu/hr
													<b>RSH</b>	=	2,709	Btu/hr
													<b>Safety Factor (15%)</b>	=	406	Btu/hr
													<b>ERSH</b>	=	3,115	Btu/hr
													<b>Airflow (20F delta T)</b>	=	144	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	243.13	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	1,141	Btu/hr				
Glass	8.75	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	294	Btu/hr				
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr				
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr			
Roof	0	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	0	Btu/hr				
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr				
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr				
Infiltration	144	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	774	Btu/hr
											<b>Heating</b>	=	2,209	Btu/hr	
											<b>Safety Factor (25%)</b>	=	552	Btu/hr	
											<b>MIN HEATING</b>	=	2,761	Btu/hr	

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.77	Btu/lb	@	79.64	F DB	,	66.14	F WB	,	16	% OA	=	4,930	Btu/hr	
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB				=	1	GPM	
	Cooling Cap	144	CFM	x	7.60	BTU/lb	x	4.5					=	351	ft2/Ton	
													<b>Tons A/C</b>	=	0.4	Tons
													<b>H2O (10F delta T)</b>	=	1	GPM
	Mix Air T-In	60	F	@	16	% OA							=			
	Heat Air T-Out	90	F										=			
	Heating Cap	144	CFM	x	30	F	x	1.08					=	4,630	Btu/hr	











# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	126 COLLECTOR OFFICE	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b> (°F-Db/°F-Wb) 75	63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b> (°F-Db/°F-Wb) 88	74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P						
Ventilation per Person		0.06	x	121	+	5	x	1	=	10.285	CFM	
per ACH		2.00	x	0	ft2	x	12.00	ft	/	60	min/hr	=
												0

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	11	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	410	Btu/hr	
	E	17	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	472	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	7	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	3	ft	x	7	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	1,306	Btu/hr
	E	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	7	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	7	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	7	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		3	ft	x	6.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	125	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	0	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		121	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt			=	454	Btu/hr		
People		1	People	x	255	Btu/hr	x	1	Diversity			=	154	Btu/hr		
Infiltration		121	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	139	Btu/hr
<b>RSH</b>													=	3,060	Btu/hr	
<b>Safety Factor (15%)</b>													=	459	Btu/hr	
<b>ERSH</b>													=	3,519	Btu/hr	
<b>Airflow (20F delta T)</b>													=	163	CFM	

*Sensible(w/o treating air)*

### III. Heating Load

Walls	313.75	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	1,472	Btu/hr				
Glass	16.25	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	545	Btu/hr				
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr				
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr			
Roof	0	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	0	Btu/hr				
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr				
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr				
Infiltration	121	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	650	Btu/hr
<b>Heating</b>											=	2,668	Btu/hr		
<b>Safety Factor (25%)</b>											=	667	Btu/hr		
<b>MIN HEATING</b>											=	3,335	Btu/hr		

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.05	Btu/lb	@	78.63	F DB	,	65.19	F WB	,	6	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	163	CFM	x	6.87	BTU/lb	x	4.5					=	5,037	Btu/hr	
													=	0.4	Tons	
													=	1	GPM	
													=	288	ft2/Ton	
	Mix Air T-In	66	F	@	6	% OA										
	Heat Air T-Out	91	F													
	Heating Cap	163	CFM	x	25	F	x	1.08					=	4,364	Btu/hr	

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary		<b>Project:</b> Boxford		<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500		201 CORRIDOR		<b>Date</b> 00.00.00
<b>By:</b>		<b>Checked By:</b>		
		<b>Project No.:</b> 17076		
<b>Design Conditions:</b>				
<b>Location</b> -	<b>Temps. Indoor</b> (°F-Db/°F-Wb) 75		<b>Summer</b> 63	<b>Winter</b> 70 °F IMC 2012, IECC 2012
	<b>Outdoor</b> (°F-Db/°F-Wb) 88		74	9 °F

### I. Outdoor Air Requirement

Area	546	ft2	A	Rp	P				
Ventilation Method per Person per ACH	0.06 2.00	x ACH	546 0	+ ft2	12.00	x	5	/	60
									32.76 CFM
									0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	S	24	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	842	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	10	ft	x	5	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	4,019	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		10	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	385	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		770	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F					=	1,540	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Lighting/Power		546	ft2	x	0.50	W/ft2	x	3.412	Btuh/Watt					=	931	Btu/hr		
People		0	People	x	255	Btu/hr	x	1	Diversity					=	0	Btu/hr		
Infiltration		546	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	626	Btu/hr
<b>RSH</b> = 8,343 Btu/hr																		
<b>Safety Factor (15%)</b> = 1,252 Btu/hr																		
<b>ERSH</b> = 9,595 Btu/hr																		
<b>Airflow (20F delta T)</b> = 444 CFM																		

### III. Heating Load

Walls					238.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	1,117	Btu/hr	
Glass					50.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	1,678	Btu/hr	
Skylight					0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr	
Roof		770	ft2	x	61	F	x	0.05	Btu/hr ft2 F					=	2,349	Btu/hr		
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F					=	0	Btu/hr		
Infiltration		546	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	2,935	Btu/hr
<b>Heating</b> = 8,078 Btu/hr																		
<b>Safety Factor (25%)</b> = 2,019 Btu/hr																		
<b>MIN HEATING</b> = 10,097 Btu/hr																		

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.12	Btu/lb	@	78.74	F DB	, 65.29	F WB	, 7	% OA					
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	, 55.0	F WB							
	Cooling Cap	444	CFM	x	6.95	BTU/lb	x	4.5						=	13,884 Btu/hr
														=	1.2 Tons
														=	3 GPM
														=	472 ft2/Ton
	Mix Air T-In	66	F	@	7	% OA									
	Heat Air T-Out	93	F												
	Heating Cap	444	CFM	x	28	F	x	1.08						=	13,215 Btu/hr

# BLW

## BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

### HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	202 CO	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>		
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74
		<b>Winter</b> 70 °F IMC 2012, IECC 2012 9 °F

#### I. Outdoor Air Requirement

Area	309	ft2												
Method	Ra	A		Rp	P									
Ventilation per Person per ACH	0.06	x	309	+	5	x	0	=						18.54 CFM
	2.00 ACH	x	0	ft2	x	12.00	ft	/	60	min/hr	=			0 CFM

#### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	S	25	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F		=	669	Btu/hr		
	E	15	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F		=	352	Btu/hr		
	W	15	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F		=	466	Btu/hr		
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	14	ft	x	8	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	8,440	Btu/hr
	E	4	ft	x	8	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	1,741	Btu/hr
	W	4	ft	x	8	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	1,365	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		21	ft	x	7.50	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F		=	1,213	Btu/hr		
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F		=	0	Btu/hr		
Roof		530	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F				=	1,060	Btu/hr			
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F				=	0	Btu/hr			
Lighting/Power		309	ft2	x	1.10	W/ft2	x	3.412	Btu/Watt				=	1,160	Btu/hr			
People		0	People	x	255	Btu/hr	x	1	Diversity				=	0	Btu/hr			
Infiltration		309	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	354	Btu/hr
													=					
													=	16,820	Btu/hr			
													=	2,523	Btu/hr			
													=	19,343	Btu/hr			
													=	896	CFM			

Sensible(w/o treating air)

#### III. Heating Load

Walls					484.50	ft2	x	61	F	x	0.08	Btu/hr ft2 F		=	2,273	Btu/hr		
Glass					157.50	ft2	x	61	F	x	0.55	Btu/hr ft2 F		=	5,284	Btu/hr		
Skylight					0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F		=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F		=	0	Btu/hr		
Roof		530	ft2	x	61	F	x	0.05	Btu/hr ft2 F				=	1,617	Btu/hr			
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F				=	0	Btu/hr			
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F				=	0	Btu/hr			
Infiltration		309	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	1,661	Btu/hr
													=					
													=	10,835	Btu/hr			
													=	2,709	Btu/hr			
													=	13,544	Btu/hr			

(not treating air)

#### IV. Furnace Specifications

AHU	Enthalpy-In	29.74	Btu/lb	@	78.21	F DB	, 64.79	F WB	, 2	% OA					
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	, 55.0	F WB							
	Cooling Cap	896	CFM	x	6.57	BTU/lb	x	4.5					=	26,472	Btu/hr
													=	2.2	Tons
													=	5	GPM
													=	140	ft2/Ton
	Mix Air T-In	69	F	@	2	% OA									
	Heat Air T-Out	86	F												
	Heating Cap	896	CFM	x	17	F	x	1.08					=	16,700	Btu/hr

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	203 JAN	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	30	ft2	A	Rp	P			
Ventilation	per Person	0.06	x	30	+	5	x	0	=
	per ACH	2.00	ACH	x	0	ft2	x	12.00	ft
							/	60	min/hr
									=
									1.8 CFM
									0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		44	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F					=	87	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Lighting/Power		30	ft2	x	0.50	W/ft2	x	3.412	Btu/h/Watt					=	51	Btu/hr		
People		0	People	x	255	Btu/hr	x	1	Diversity					=	0	Btu/hr		
Infiltration		0	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	0	Btu/hr

<b>RSH</b>	=	138	Btu/hr
<b>Safety Factor (15%)</b>	=	21	Btu/hr
<b>ERSH</b>	=	159	Btu/hr
<b>Airflow (20F delta T)</b>	=	7	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls		0.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	0	Btu/hr				
Glass		0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	0	Btu/hr				
Skylight		0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr				
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr	
Roof		44	ft2	x	61	F	x	0.05	Btu/hr ft2 F			=	133	Btu/hr				
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F			=	0	Btu/hr				
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F			=	0	Btu/hr				
Infiltration		0	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	0	Btu/hr

<b>Heating</b>	=	133	Btu/hr
<b>Safety Factor (25%)</b>	=	33	Btu/hr
<b>MIN HEATING</b>	=	166	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	31.36	Btu/lb	@	80.45	F DB	,	66.90	F WB	,	24	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	7	CFM	x	8.19	BTU/lb	x	4.5						=	271	Btu/hr
														=	0.0	Tons
														=	0	GPM
														=	1328	ft2/Ton
	Mix Air T-In	55	F	@	24	% OA										
	Heat Air T-Out	93	F													
	Heating Cap	7	CFM	x	38	F	x	1.08						=	300	Btu/hr













# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	209 WOMEN	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	50	ft2	A	Rp	P							
Ventilation	per Person	0.06	x	50	+	5	x	1	=	8 CFM			
	per ACH	2.00	x	0	ft2	x	12.00	ft	/	60	min/hr	=	0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		73	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	145	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		50	ft2	x	0.90	W/ft2	x	3.412	Btu/h/Watt			=	154	Btu/hr		
People		1	People	x	255	Btu/hr	x	1	Diversity			=	255	Btu/hr		
Infiltration		0	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	0	Btu/hr
<b>RSH</b>													=	554	Btu/hr	
<b>Sensible(w/o treating air)</b>													=	83	Btu/hr	
<b>Safety Factor (15%)</b>													=	637	Btu/hr	
<b>ERSH</b>													=	29	CFM	
<b>Airflow (20F delta T)</b>													=			

### III. Heating Load

Walls	0.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
Glass	0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr		
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr		
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr	
Roof	73	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	221	Btu/hr		
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr		
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr		
Infiltration	0	ft2	x	12.00	ft	x	61	F x 1.08	x 0.4 ACH x 0.017	min/hr	=	0	Btu/hr
<b>Heating</b>											=	221	Btu/hr
<b>Safety Factor (25%)</b>											=	55	Btu/hr
<b>MIN HEATING</b>											=	276	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	31.56	Btu/lb	@	80.71	F DB	,	67.15	F WB	,	27	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	29	CFM	x	8.39	BTU/lb	x	4.5					=	1,112	Btu/hr	
													=	0.1	Tons	
													=	0	GPM	
													=	539	ft2/Ton	
	Mix Air T-In	53	F	@	27	% OA										
	Heat Air T-Out	81	F													
	Heating Cap	29	CFM	x	27	F	x	1.08					=	867	Btu/hr	

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	210 STAIR #1	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b> (°F-Db/°F-Wb) 75	63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b> (°F-Db/°F-Wb) 88	74	9 °F

### I. Outdoor Air Requirement

Area	116	ft2	A	Rp	P	0	=	6.96 CFM
Ventilation Method	0.06	x	116	+	5	x		
per Person	2.00	ACH	x	0	ft2	x	12.00	ft / 60 min/hr = 0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		168	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	336	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		116	ft2	x	0.50	W/ft2	x	3.412	Btu/h/Watt			=	198	Btu/hr		
People		0	People	x	255	Btu/hr	x	1	Diversity			=	0	Btu/hr		
Infiltration		116	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017 min/hr	=	133	Btu/hr	

<b>RSH</b>	=	667	Btu/hr
<b>Safety Factor (15%)</b>	=	100	Btu/hr
<b>ERSH</b>	=	767	Btu/hr
<b>Airflow (20F delta T)</b>	=	36	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	0.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr
Roof	168	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	513	Btu/hr	
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr	
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr	
Infiltration	116	ft2	x	12.00	ft	x	61	F x 1.08	x 0.4 ACH x 0.017 min/hr	=	624	Btu/hr

<b>Heating</b>	=	1,137	Btu/hr
<b>Safety Factor (25%)</b>	=	284	Btu/hr
<b>MIN HEATING</b>	=	1,421	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	31.00	Btu/lb	@	79.96	F DB	,	66.44	F WB	,	20	% OA	=	1,252	Btu/hr
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB				=	0.1	Tons
	Cooling Cap	36	CFM	x	7.83	BTU/lb	x	4.5					=	0	GPM
													=	1112	ft2/Ton
	Mix Air T-In	58	F	@	20	% OA							=		
	Heat Air T-Out	109	F										=		
	Heating Cap	36	CFM	x	51	F	x	1.08					=	1,956	Btu/hr





# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	213 STAIR #3	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	94	ft2	A	Rp	P						
Ventilation	per Person	0.06	x	94	+	5	x	0	=	5.64	CFM	
	per ACH	2.00	ACH	x	0	ft2	x	12.00	ft	/	60	min/hr
									=		0	CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		136	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	273	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		94	ft2	x	0.50	W/ft2	x	3.412	Btu/h/Watt			=	160	Btu/hr		
People		0	People	x	255	Btu/hr	x	1	Diversity			=	0	Btu/hr		
Infiltration		0	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	0	Btu/hr

<b>RSH</b>	=	433	Btu/hr
<b>Safety Factor (15%)</b>	=	65	Btu/hr
<b>ERSH</b>	=	498	Btu/hr
<b>Airflow (20F delta T)</b>	=	23	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	0.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	0	Btu/hr				
Glass	0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr				
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr				
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr			
Roof	136	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	416	Btu/hr				
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr				
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr				
Infiltration	0	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	0	Btu/hr

<b>Heating</b>	=	416	Btu/hr
<b>Safety Factor (25%)</b>	=	104	Btu/hr
<b>MIN HEATING</b>	=	520	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	31.36	Btu/lb	@	80.45	F DB	,	66.90	F WB	,	24	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	23	CFM	x	8.19	BTU/lb	x	4.5					=	849	Btu/hr	
													=	0.1	Tons	
													=	0	GPM	
													=	1328	ft2/Ton	
	Mix Air T-In	55	F	@	24	% OA										
	Heat Air T-Out	93	F													
	Heating Cap	23	CFM	x	38	F	x	1.08					=	941	Btu/hr	

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	214 ADMIN WAITING	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b> (°F-Db/°F-Wb) 75	63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b> (°F-Db/°F-Wb) 88	74	9 °F

### I. Outdoor Air Requirement

Area	373	ft2	A	Rp	P	4	=	41.03 CFM
Ventilation Method	0.06	x	373	+	5	x		
per Person	2.00	ACH	x	0	ft2	x	12.00	ft / 60 min/hr = 0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	5	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	189	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		541	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F				=	1,082	Btu/hr	
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F				=	0	Btu/hr	
Lighting/Power		373	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt				=	1,400	Btu/hr	
People		4	People	x	255	Btu/hr	x	1	Diversity				=	951	Btu/hr	
Infiltration		373	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017 min/hr	=	427	Btu/hr	

<b>RSH</b>	=	4,049	Btu/hr
<b>Safety Factor (15%)</b>	=	607	Btu/hr
<b>ERSH</b>	=	4,657	Btu/hr
<b>Airflow (20F delta T)</b>	=	216	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	60.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	282	Btu/hr	
Glass	0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr
Roof	541	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	1,650	Btu/hr	
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr	
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr	
Infiltration	373	ft2	x	12.00	ft	x	61	F x 1.08	x 0.4 ACH x 0.017 min/hr	=	2,005	Btu/hr

<b>Heating</b>	=	3,936	Btu/hr
<b>Safety Factor (25%)</b>	=	984	Btu/hr
<b>MIN HEATING</b>	=	4,920	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.96	Btu/lb	@	79.90	F DB	,	66.39	F WB	,	19	% OA	=	7,556	Btu/hr
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB				=		
	Cooling Cap	216	CFM	x	7.79	BTU/lb	x	4.5					=	2	GPM
													=	0.6	Tons
													=	592	ft2/Ton
	Mix Air T-In	58	F	@	19	% OA							=		
	Heat Air T-Out	93	F										=		
	Heating Cap	216	CFM	x	35	F	x	1.08					=	8,089	Btu/hr

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	215 FINANCE OFFICE	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	341	ft2	A	Rp	P	=	
Ventilation per Person per ACH	Ra	0.06	x	341	+	5	x	2
	ACH	2.00	x	0	ft2	x	12.00	ft
						/		60
								min/hr
								=
								28.985 CFM
								=
								0 CFM

### II. Sensible Cooling Load

Walls	N	10	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	146	Btu/hr			
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	E	9	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	239	Btu/hr			
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
Glass	N	8	ft	x	5	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	1,195	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	3	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	829	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		10	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	385	Btu/hr			
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr			
Roof		494	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	989	Btu/hr				
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr				
Lighting/Power		341	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt			=	1,280	Btu/hr				
People		2	People	x	255	Btu/hr	x	1	Diversity			=	435	Btu/hr				
Infiltration		341	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	391	Btu/hr

<b>RSH</b>	=	5,889	Btu/hr
<b>Safety Factor (15%)</b>	=	883	Btu/hr
<b>ERSH</b>	=	6,772	Btu/hr
<b>Airflow (20F delta T)</b>	=	314	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	182.80	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	858	Btu/hr						
Glass	50.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	1,678	Btu/hr						
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr						
Door	0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F						
Roof	494	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	1,508	Btu/hr						
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr						
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr						
Infiltration	341	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	1,833	Btu/hr

<b>Heating</b>	=	5,876	Btu/hr
<b>Safety Factor (25%)</b>	=	1,469	Btu/hr
<b>MIN HEATING</b>	=	7,346	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.25	Btu/lb	@	78.92	F DB	,	65.47	F WB	,	9	% OA	=	
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB				=	
	Cooling Cap	314	CFM	x	7.08	BTU/lb	x	4.5					=	9,988
													=	0.8
													=	2
													=	410
	Mix Air T-In	64	F	@	9	% OA							=	
	Heat Air T-Out	94	F										=	
	Heating Cap	314	CFM	x	29	F	x	1.08					=	9,932



# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

Project phase: Preliminary	Project: <b>Boxford</b>	Sheet: 1 of 1
Trade Specification Section: 15500	217 FINANCE DIRECTOR	Date
By: _____	Project No.: 17076	00.00.00

Design Conditions:			
Location	Temps.	Summer	Winter
-	Indoor	(°F-Db/°F-Wb) 75	63 70 °F IMC 2012, IECC 2012
	Outdoor	(°F-Db/°F-Wb) 88	74 9 °F

### I. Outdoor Air Requirement

Area	Method	137	ft2	A	Rp	P					
Ventilation	per Person	0.06	x	137	+	5	x	1	=	13.22	CFM
	per ACH	2.00	x	0	ft2	x	12.00	ft	/	60	min/hr
									=	0	CFM

### II. Sensible Cooling Load

Walls	N	11	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F		=	211	Btu/hr		
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	E	16	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F		=	421	Btu/hr		
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F		=	0	Btu/hr		
Glass	N	3	ft	x	5	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	398	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	3	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	829	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		5	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F		=	193	Btu/hr		
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F		=	0	Btu/hr		
Roof		199	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F				=	397	Btu/hr			
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F				=	0	Btu/hr			
Lighting/Power		137	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt				=	514	Btu/hr			
People		1	People	x	255	Btu/hr	x	1	Diversity				=	255	Btu/hr			
Infiltration		137	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	157	Btu/hr
<b>RSH</b>															=	3,376	Btu/hr	
<b>Sensible(w/o treating air)</b>															<b>Safety Factor (15%)</b>	=	506	Btu/hr
															<b>ERSH</b>	=	3,882	Btu/hr
															<b>Airflow (20F delta T)</b>	=	180	CFM

### III. Heating Load

Walls					296.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F		=	1,389	Btu/hr		
Glass					25.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F		=	839	Btu/hr		
Skylight					0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F		=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F		=	0	Btu/hr		
Roof		199	ft2	x	61	F	x	0.05	Btu/hr ft2 F				=	606	Btu/hr			
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F				=	0	Btu/hr			
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F				=	0	Btu/hr			
Infiltration		137	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	736	Btu/hr
<b>Heating</b>															=	3,570	Btu/hr	
<b>(not treating air)</b>															<b>Safety Factor (25%)</b>	=	893	Btu/hr
															<b>MIN HEATING</b>	=	4,463	Btu/hr

### IV. Furnace Specifications

AHU	Enthalpy-In	30.12	Btu/lb	@	78.74	F DB	,	65.29	F WB	,	7	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	180	CFM	x	6.94	BTU/lb	x	4.5						=	5,617	Btu/hr
														=	0.5	Tons
														=	1	GPM
														=	293	ft2/Ton
	Mix Air T-In	66	F	@	7	% OA										
	Heat Air T-Out	95	F													
	Heating Cap	180	CFM	x	29	F	x	1.08						=	5,722	Btu/hr

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

Project phase: Preliminary	Project: <b>Boxford</b>	Sheet: 1 of 1
Trade Specification Section: 15500	218 MAIL/COPY	Date
By: _____	Project No.: 17076	00.00.00

Design Conditions:			
Location	Temps.	Summer	Winter
-	Indoor	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	Outdoor	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P								
Ventilation	per Person	0.06	x	182	+	5	x	2	=	20.92 CFM				
	per ACH	2.00 ACH	x	0	ft2	x	12.00	ft	/	60	min/hr	=	0 CFM	

### II. Sensible Cooling Load

Walls	N	10	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	219	Btu/hr		
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
	E	11	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	248	Btu/hr		
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr	
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr	
	E	5	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	1,658	Btu/hr	
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr	
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr	
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr	
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr	
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr	
Glass		5	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	193	Btu/hr		
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr		
Roof		264	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	528	Btu/hr			
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr			
Lighting/Power		182	ft2	x	2.00	W/ft2	x	3.412	Btu/Watt			=	1,242	Btu/hr			
People		2	People	x	255	Btu/hr	x	1	Diversity			=	510	Btu/hr			
Infiltration		182	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	209	Btu/hr	
<b>RSH</b>														=	4,806	Btu/hr	
<b>Safety Factor (15%)</b>														=	721	Btu/hr	
<i>Sensible(w/o treating air)</i>														<b>ERSH</b>	=	5,527	Btu/hr
<b>Airflow (20F delta T)</b>														=	256	CFM	

### III. Heating Load

Walls	227.60	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	1,068	Btu/hr				
Glass	25.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	839	Btu/hr				
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr				
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr			
Roof	264	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	805	Btu/hr				
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr				
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr				
Infiltration	182	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	978	Btu/hr
<b>Heating</b>											=	3,690	Btu/hr		
<b>Safety Factor (25%)</b>											=	923	Btu/hr		
(not treating air)											<b>MIN HEATING</b>	=	4,613	Btu/hr	

### IV. Furnace Specifications

AHU	Enthalpy-In	30.18	Btu/lb	@	78.82	F DB	,	65.37	F WB	,	8	% OA			
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB						
	Cooling Cap	256	CFM	x	7.00	BTU/lb	x	4.5					=	8,063	Btu/hr
													=	0.7	Tons
													=	2	GPM
													=	271	ft2/Ton
	Mix Air T-In	65	F	@	8	% OA									
	Heat Air T-Out	89	F												
	Heating Cap	256	CFM	x	24	F	x	1.08					=	6,543	Btu/hr

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	219 DEAD FILE STORAGE	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P						
Ventilation	per Person	0.06	x	89	+	5	x	0	=	5.34	CFM	
	per ACH	2.00	ACH	x	0	ft2	x	12.00	ft	/	60	min/hr
									=		0	CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		129	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	258	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		89	ft2	x	0.50	W/ft2	x	3.412	Btu/h/Watt			=	152	Btu/hr		
People		0	People	x	255	Btu/hr	x	1	Diversity			=	0	Btu/hr		
Infiltration		0	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	0	Btu/hr

<b>RSH</b>	=	410	Btu/hr
<b>Safety Factor (15%)</b>	=	61	Btu/hr
<b>ERSH</b>	=	471	Btu/hr
<b>Airflow (20F delta T)</b>	=	22	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	0.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	0	Btu/hr		
Glass	0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr		
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr		
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr	
Roof	129	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	394	Btu/hr		
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr		
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr		
Infiltration	0	ft2	x	12.00	ft	x	61	F x 1.08	x 0.4 ACH x 0.017	min/hr	=	0	Btu/hr

<b>Heating</b>	=	394	Btu/hr
<b>Safety Factor (25%)</b>	=	98	Btu/hr
<b>MIN HEATING</b>	=	492	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	31.36	Btu/lb	@	80.45	F DB	,	66.90	F WB	,	24	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	22	CFM	x	8.19	BTU/lb	x	4.5					=	804	Btu/hr	
													=	0.1	Tons	
													=	0	GPM	
													=	1328	ft2/Ton	
	Mix Air T-In	55	F	@	24	% OA										
	Heat Air T-Out	93	F													
	Heating Cap	22	CFM	x	38	F	x	1.08					=	891	Btu/hr	

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	220 SELECTMEN	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75   63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88   74	9 °F

### I. Outdoor Air Requirement

Area	Method	285	ft2	A	Rp	P						
Ventilation per Person	Ra	0.06	x	285	+	5	x	1	=	24,225	CFM	
per ACH		2.00	ACH	x	0	ft2	x	12.00	ft	/	60	min/hr
									=	0	CFM	

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	16	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	547	Btu/hr	
	E	20	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	513	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	8	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	3,014	Btu/hr
	E	5	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	1,658	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		13	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	481	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		413	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	827	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		285	ft2	x	1.10	W/ft2	x	3.412	Btu/Watt			=	1,070	Btu/hr		
People		1	People	x	255	Btu/hr	x	1	Diversity			=	363	Btu/hr		
Infiltration		285	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	327	Btu/hr
													<b>RSH</b>	=	8,799	Btu/hr
													<b>Safety Factor (15%)</b>	=	1,320	Btu/hr
													<b>ERSH</b>	=	10,119	Btu/hr
													<b>Airflow (20F delta T)</b>	=	468	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	369.50	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	1,734	Btu/hr			
Glass	62.50	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	2,097	Btu/hr			
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr			
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr		
Roof	413	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	1,260	Btu/hr			
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr			
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr			
Infiltration	285	ft2	x	12.00	ft	x	61	F x 1.08	x 0.4 ACH x 0.017	min/hr	=	1,532	Btu/hr	
											<b>Heating</b>	=	6,623	Btu/hr
											<b>Safety Factor (25%)</b>	=	1,656	Btu/hr
											<b>MIN HEATING</b>	=	8,279	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	29.96	Btu/lb	@	78.52	F DB	,	65.09	F WB	,	5	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	468	CFM	x	6.79	BTU/lb	x	4.5					=	14,312	Btu/hr	
													=	1.2	Tons	
													=	3	GPM	
													=	239	ft2/Ton	
	Mix Air T-In	67	F	@	5	% OA										
	Heat Air T-Out	88	F													
	Heating Cap	468	CFM	x	22	F	x	1.08					=	10,887	Btu/hr	



# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	221 ASSISTANT ADMINISTRATOR	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b> (°F-Db/°F-Wb) 75	63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b> (°F-Db/°F-Wb) 88	74	9 °F

### I. Outdoor Air Requirement

Area	183	ft2	A	Rp	P	1	=	15.555 CFM
Ventilation Method	0.06	x	183	+	5	x		
per Person	2.00	ACH	x	0	ft2	x	12.00	ft / 60 min/hr = 0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	10	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	425	Btu/hr	
	E	10	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	236	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	5	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	1,658	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		5	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	193	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		265	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	531	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		183	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt			=	687	Btu/hr		
People		1	People	x	255	Btu/hr	x	1	Diversity			=	233	Btu/hr		
Infiltration		183	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017 min/hr	=	210	Btu/hr	

<b>RSH</b>	=	4,172	Btu/hr
<b>Safety Factor (15%)</b>	=	626	Btu/hr
<b>ERSH</b>	=	4,798	Btu/hr
<b>Airflow (20F delta T)</b>	=	222	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	218.96	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	1,027	Btu/hr	
Glass	25.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	839	Btu/hr	
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr
Roof	265	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	809	Btu/hr	
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr	
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr	
Infiltration	183	ft2	x	12.00	ft	x	61	F x 1.08	x 0.4 ACH x 0.017 min/hr	=	984	Btu/hr

<b>Heating</b>	=	3,659	Btu/hr
<b>Safety Factor (25%)</b>	=	915	Btu/hr
<b>MIN HEATING</b>	=	4,574	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.09	Btu/lb	@	78.70	F DB	,	65.26	F WB	,	7	% OA	=	6,916	Btu/hr
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB				=		
	Cooling Cap	222	CFM	x	6.92	BTU/lb	x	4.5					=	0.6	Tons
													=	1	GPM
													=	318	ft2/Ton
	Mix Air T-In	66	F	@	7	% OA							=		
	Heat Air T-Out	91	F										=		
	Heating Cap	222	CFM	x	25	F	x	1.08					=	6,079	Btu/hr

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

Project phase: Preliminary	Project: <b>Boxford</b>	222 TOWN ADMINISTRATOR	<b>Sheet</b>
Trade Specification Section: 15500			1 of 1
By: _____	Checked By: _____	Project No.: <b>17076</b>	<b>Date</b>
Design Conditions:			00.00.00
Location	Temps.	Summer	Winter
-	Indoor	(°F-Db/°F-Wb) 75	63 70 °F IMC 2012, IECC 2012
	Outdoor	(°F-Db/°F-Wb) 88	74 9 °F

### I. Outdoor Air Requirement

Area	Method	288	ft2																
Ventilation	per Person	0.06	x	288															24.48 CFM
	per ACH	2.00	x	0	ft2	x	12.00	ft	/	60	min/hr	=							0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	S	17	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	579	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	21	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	716	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	8	ft	x	5	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	3,014	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	5	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	1,300	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		13	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	481	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		418	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F					=	835	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Lighting/Power		288	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt					=	1,081	Btu/hr		
People		1	People	x	255	Btu/hr	x	1	Diversity					=	367	Btu/hr		
Infiltration		288	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	330	Btu/hr
<b>RSH</b>															=	8,703	Btu/hr	
<b>Safety Factor (15%)</b>															=	1,305	Btu/hr	
<b>ERSH</b>															=	10,009	Btu/hr	
<b>Airflow (20F delta T)</b>															=	463	CFM	

*Sensible(w/o treating air)*

### III. Heating Load

Walls					390.50	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	1,832	Btu/hr	
Glass					62.50	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	2,097	Btu/hr	
Skylight					0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr	
Roof		418	ft2	x	61	F	x	0.05	Btu/hr ft2 F					=	1,274	Btu/hr		
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F					=	0	Btu/hr		
Infiltration		288	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	1,548	Btu/hr
<b>Heating</b>															=	6,751	Btu/hr	
<b>Safety Factor (25%)</b>															=	1,688	Btu/hr	
<b>MIN HEATING</b>															=	8,439	Btu/hr	

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	29.97	Btu/lb	@	78.53	F DB	,	65.10	F WB	,	5	% OA						
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB									
	Cooling Cap	463	CFM	x	6.80	BTU/lb	x	4.5							=	14,172	Btu/hr	
															=	1.2	Tons	
															=	3	GPM	
															=	244	ft2/Ton	
	Mix Air T-In	67	F	@	5	% OA												
	Heat Air T-Out	89	F															
	Heating Cap	463	CFM	x	22	F	x	1.08							=	11,053	Btu/hr	

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	223 REGULATORY WAITING	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75   63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88   74	9 °F

### I. Outdoor Air Requirement

Area	354	ft2																		
Method	Ra	A	+	+	+	+	+	+	+	+	+	+	+	+	+	+	+	+	+	+
Ventilation per Person	0.06	x	354																	
per ACH	2.00	x	0	ft2	x	12.00	ft	/	60	min/hr	=	38.94	CFM							

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	E	5	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	143	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		513	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	1,027	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		354	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt			=	1,329	Btu/hr		
People		4	People	x	255	Btu/hr	x	1	Diversity			=	903	Btu/hr		
Infiltration		354	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017 min/hr	=	406	Btu/hr	
												=	3,807	Btu/hr		
												=	571	Btu/hr		
												=	4,378	Btu/hr		
												=	203	CFM		

### III. Heating Load

Walls	60.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	282	Btu/hr	
Glass	0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr	
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr
Roof	513	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	1,566	Btu/hr	
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr	
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr	
Infiltration	354	ft2	x	12.00	ft	x	61	F x 1.08	x 0.4 ACH x 0.017 min/hr	=	1,903	Btu/hr
									=	3,750	Btu/hr	
									=	938	Btu/hr	
									=	4,688	Btu/hr	

### IV. Furnace Specifications

AHU	Enthalpy-In	30.98	Btu/lb	@	79.92	F DB	,	66.41	F WB	,	19	% OA								
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB											
	Cooling Cap	203	CFM	x	7.80	BTU/lb	x	4.5					=	7,115	Btu/hr					
													=	0.6	Tons					
													=	1	GPM					
													=	597	ft2/Ton					
	Mix Air T-In	58	F	@	19	% OA														
	Heat Air T-Out	93	F																	
	Heating Cap	203	CFM	x	35	F	x	1.08					=	7,691	Btu/hr					

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

Project phase: Preliminary	Project: <b>Boxford</b>	Sheet 1 of 1
Trade Specification Section: 15500	224 INSPECTIONAL DEPT.	Date
By: _____	Project No.: <b>17076</b>	00.00.00

Design Conditions:			
Location	Temps.	Summer	Winter
-	Indoor	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	Outdoor	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	280	ft2	A	Rp	P						
Ventilation	per Person	0.06	x	280	+	5	x	1				= 23.8 CFM
	per ACH	2.00 ACH	x	0	ft2	x	12.00	ft	/	60	min/hr	= 0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	S	16	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	547	Btu/hr	
	E	21	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	541	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	8	ft	x	5	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	3,014	Btu/hr
	E	5	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	1,658	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		13	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	481	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		406	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F					=	812	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Lighting/Power		280	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt					=	1,051	Btu/hr		
People		1	People	x	255	Btu/hr	x	1	Diversity					=	357	Btu/hr		
Infiltration		280	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	321	Btu/hr
<b>RSH</b>															=	8,783	Btu/hr	
<b>Safety Factor (15%)</b>															=	1,317	Btu/hr	
<b>ERSH</b>															=	10,100	Btu/hr	
<b>Airflow (20F delta T)</b>															=	468	CFM	

Sensible(w/o treating air)

### III. Heating Load

Walls		381.50	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	1,790	Btu/hr				
Glass		62.50	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	2,097	Btu/hr				
Skylight		0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr				
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr	
Roof		406	ft2	x	61	F	x	0.05	Btu/hr ft2 F			=	1,238	Btu/hr				
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F			=	0	Btu/hr				
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F			=	0	Btu/hr				
Infiltration		280	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	1,505	Btu/hr
<b>Heating</b>															=	6,631	Btu/hr	
<b>Safety Factor (25%)</b>															=	1,658	Btu/hr	
<b>MIN HEATING</b>															=	8,288	Btu/hr	

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	29.96	Btu/lb	@	78.51	F DB	,	65.08	F WB	,	5	% OA					
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB								
	Cooling Cap	468	CFM	x	6.78	BTU/lb	x	4.5								=	14,273 Btu/hr
																=	1.2 Tons
																=	3 GPM
																=	235 ft2/Ton
	Mix Air T-In	67	F	@	5	% OA											
	Heat Air T-Out	88	F														
	Heating Cap	468	CFM	x	22	F	x	1.08								=	10,866 Btu/hr

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	225 BUILDING INSPECTOR	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	128	ft2	A	Rp	P	10.88 CFM
Ventilation	per Person	0.06	x	128	+	5	=
	per ACH	2.00	x	0	ft2	x	12.00
					ft	/	60
							=
							0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	16	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	547	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	10	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	349	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	8	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	3,014	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	3	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	650	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		10	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	385	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		186	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	371	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		128	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt			=	480	Btu/hr		
People		1	People	x	255	Btu/hr	x	1	Diversity			=	163	Btu/hr		
Infiltration		128	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	147	Btu/hr
<b>RSH</b>													=	6,106	Btu/hr	
<b>Safety Factor (15%)</b>													=	916	Btu/hr	
<b>ERSH</b>													=	7,022	Btu/hr	
<b>Airflow (20F delta T)</b>													=	325	CFM	

*Sensible(w/o treating air)*

### III. Heating Load

Walls	265.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	1,243	Btu/hr				
Glass	50.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	1,678	Btu/hr				
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr				
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr			
Roof	186	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	566	Btu/hr				
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr				
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr				
Infiltration	128	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	688	Btu/hr
<b>Heating</b>											=	4,175	Btu/hr		
<b>Safety Factor (25%)</b>											=	1,044	Btu/hr		
<b>MIN HEATING</b>											=	5,219	Btu/hr		

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	29.83	Btu/lb	@	78.33	F DB	,	64.91	F WB	,	3	% OA	=	9,742	Btu/hr
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB						
	Cooling Cap	325	CFM	x	6.66	BTU/lb	x	4.5							
<b>Tons A/C</b>													=	0.8	Tons
<b>H2O (10F delta T)</b>													=	2	GPM
	Mix Air T-In	68	F	@	3	% OA									
	Heat Air T-Out	87	F												
	Heating Cap	325	CFM	x	19	F	x	1.08							

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

Project phase: Preliminary	Project: <b>Boxford</b>	Sheet: 1 of 1
Trade Specification Section: 15500	226 ZBA	Date
By: _____	Project No.: 17076	00.00.00

Design Conditions:			
Location	Temps.	Summer	Winter
-	Indoor	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	Outdoor	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	156	ft2																
Ventilation	per Person	0.06	x	156															13.26 CFM
	per ACH	2.00	x	0	ft2	x	12.00	ft	/	60	min/hr	=							0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	W	10	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	330	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	3	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	650	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		3	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	96	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Roof		226	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F					=	452	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Lighting/Power		156	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt					=	585	Btu/hr		
People		1	People	x	255	Btu/hr	x	1	Diversity					=	199	Btu/hr		
Infiltration		156	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	179	Btu/hr
<b>RSH</b>															=	2,491	Btu/hr	
<b>Safety Factor (15%)</b>															=	374	Btu/hr	
<b>ERSH</b>															=	2,865	Btu/hr	
<b>Airflow (20F delta T)</b>															=	133	CFM	

*Sensible(w/o treating air)*

### III. Heating Load

Walls					104.50	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	490	Btu/hr	
Glass					12.50	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	419	Btu/hr	
Skylight					0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr	
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr	
Roof		226	ft2	x	61	F	x	0.05	Btu/hr ft2 F					=	690	Btu/hr		
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F					=	0	Btu/hr		
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F					=	0	Btu/hr		
Infiltration		156	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	839	Btu/hr
<b>Heating</b>															=	2,438	Btu/hr	
<b>Safety Factor (25%)</b>															=	610	Btu/hr	
<b>MIN HEATING</b>															=	3,048	Btu/hr	

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.31	Btu/lb	@	79.00	F DB	,	65.54	F WB	,	10	% OA						
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB									
	Cooling Cap	133	CFM	x	7.13	BTU/lb	x	4.5							=	4,258	Btu/hr	
															=	0.4	Tons	
															=	1	GPM	
															=	440	ft2/Ton	
	Mix Air T-In	64	F	@	10	% OA												
	Heat Air T-Out	93	F															
	Heating Cap	133	CFM	x	29	F	x	1.08							=	4,208	Btu/hr	

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	227 HEALTH	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75   63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88   74	9 °F

### I. Outdoor Air Requirement

Area	Method	248	ft2	A	Ra	A	Rp	P	1	=	21.08 CFM
Ventilation	per Person	0.06	x	248				5	x		
	per ACH	2.00 ACH	x	0	ft2	x	12.00	ft	/	60	min/hr
											= 0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	S	10	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	437	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	10	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	292	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	5	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	1,300	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		5	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	193	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		360	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	719	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		248	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt			=	931	Btu/hr		
People		1	People	x	255	Btu/hr	x	1	Diversity			=	316	Btu/hr		
Infiltration		248	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	284	Btu/hr

<b>RSH</b>	=	4,472	Btu/hr
<b>Safety Factor (15%)</b>	=	671	Btu/hr
<b>ERSH</b>	=	5,143	Btu/hr
<b>Airflow (20F delta T)</b>	=	238	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	216.32	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	1,015	Btu/hr				
Glass	25.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	839	Btu/hr				
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr				
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr			
Roof	360	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	1,097	Btu/hr				
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr				
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr				
Infiltration	248	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	1,333	Btu/hr

<b>Heating</b>	=	4,284	Btu/hr
<b>Safety Factor (25%)</b>	=	1,071	Btu/hr
<b>MIN HEATING</b>	=	5,355	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.23	Btu/lb	@	78.89	F DB	,	65.43	F WB	,	9	% OA	=	7,556	Btu/hr
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB						
	Cooling Cap	238	CFM	x	7.05	BTU/lb	x	4.5					=	0.6	Tons
													=	2	GPM
													=	394	ft2/Ton
	Mix Air T-In	65	F	@	9	% OA									
	Heat Air T-Out	93	F												
	Heating Cap	238	CFM	x	28	F	x	1.08					=	7,258	Btu/hr

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	228 HEALTH DIRECTOR	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b> (°F-Db/°F-Wb) 75	63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b> (°F-Db/°F-Wb) 88	74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P						
Ventilation	per Person	0.06	x	127	+	5	x	1	=	10.795	CFM	
	per ACH	2.00	x	0	ft2	x	12.00	ft	/	60	min/hr	=
												0

### II. Sensible Cooling Load

Walls	N	10	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	219	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	12	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	356	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	5	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	1,300	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		5	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	193	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		184	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	368	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		127	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt			=	477	Btu/hr		
People		1	People	x	255	Btu/hr	x	1	Diversity			=	162	Btu/hr		
Infiltration		127	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	145	Btu/hr
<b>RSH</b>													=	3,220	Btu/hr	
<b>Safety Factor (15%)</b>													=	483	Btu/hr	
<b>ERSH</b>													=	3,703	Btu/hr	
<b>Airflow (20F delta T)</b>													=	171	CFM	

*Sensible(w/o treating air)*

### III. Heating Load

Walls	236.96	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	1,112	Btu/hr				
Glass	25.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	839	Btu/hr				
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr				
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr			
Roof	184	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	562	Btu/hr				
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr				
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr				
Infiltration	127	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	683	Btu/hr
<b>Heating</b>											=	3,195	Btu/hr		
<b>Safety Factor (25%)</b>											=	799	Btu/hr		
<b>MIN HEATING</b>											=	3,994	Btu/hr		

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.04	Btu/lb	@	78.63	F DB	,	65.19	F WB	,	6	% OA				
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB							
	Cooling Cap	171	CFM	x	6.87	BTU/lb	x	4.5					=	5,300	Btu/hr	
													=	0.4	Tons	
													=	1	GPM	
													=	288	ft2/Ton	
	Mix Air T-In	66	F	@	6	% OA										
	Heat Air T-Out	94	F													
	Heating Cap	171	CFM	x	27	F	x	1.08					=	5,075	Btu/hr	





# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

Project phase: Preliminary	Project: Boxford	Sheet 1 of 1
Trade Specification Section: 15500	230 CONSERVATION DIRECTOR	Date
By: _____	Project No.: 17076	00.00.00

Design Conditions:			
Location	Temps.	Summer	Winter
-	Indoor	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	Outdoor	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P	min/hr	=	
Ventilation per Person		0.06	x	109	+	5	x	1	9,265 CFM
per ACH		2.00 ACH	x	0	ft2	x	12.00	ft	/
									60
									=
									0 CFM

### II. Sensible Cooling Load

Walls	N	11	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	207	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	13	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	465	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	3	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	398	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	3	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	650	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		5	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	193	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		158	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	316	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		109	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt			=	409	Btu/hr		
People		1	People	x	255	Btu/hr	x	1	Diversity			=	139	Btu/hr		
Infiltration		109	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	125	Btu/hr

RSH	=	2,902	Btu/hr
Safety Factor (15%)	=	435	Btu/hr
ERSH	=	3,337	Btu/hr
Airflow (20F delta T)	=	155	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	264.56	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	1,241	Btu/hr				
Glass	25.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	839	Btu/hr				
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr				
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr			
Roof	158	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	482	Btu/hr				
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr				
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr				
Infiltration	109	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	586	Btu/hr

Heating	=	3,148	Btu/hr
Safety Factor (25%)	=	787	Btu/hr
MIN HEATING	=	3,935	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.02	Btu/lb	@	78.60	F DB	,	65.16	F WB	,	6	% OA	=		
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB				=		
	Cooling Cap	155	CFM	x	6.85	BTU/lb	x	4.5					=	4,761	Btu/hr
													=	0.4	Tons
													=	1	GPM
													=	275	ft2/Ton
	Mix Air T-In	66	F	@	6	% OA							=		
	Heat Air T-Out	96	F										=		
	Heating Cap	155	CFM	x	29	F	x	1.08					=	4,879	Btu/hr

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

Project phase: Preliminary	Project: Boxford	Sheet 1 of 1
Trade Specification Section: 15500	231 CONSERVATION ASSISTANT	Date
By: _____	Project No.: 17076	00.00.00

Design Conditions:			
Location	Temps.	Summer	Winter
-	Indoor	(°F-Db/°F-Wb) 75	63 70 °F IMC 2012, IECC 2012
	Outdoor	(°F-Db/°F-Wb) 88	74 9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P	min/hr	=	10.03 CFM
Ventilation per Person	0.06	x	118	+	5	x	1	=	10.03 CFM
per ACH	2.00 ACH	x	0	ft2	x	12.00	ft	/	60
									0 CFM

### II. Sensible Cooling Load

Walls	N	10	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	153	Btu/hr	
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr	
Glass	N	8	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	1,195	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr
Glass		8	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	289	Btu/hr	
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr	
Roof		171	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	342	Btu/hr		
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr		
Lighting/Power		118	ft2	x	1.10	W/ft2	x	3.412	Btu/h/Watt			=	443	Btu/hr		
People		1	People	x	255	Btu/hr	x	1	Diversity			=	150	Btu/hr		
Infiltration		118	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	135	Btu/hr

RSH	=	2,708	Btu/hr
Safety Factor (15%)	=	406	Btu/hr
ERSH	=	3,114	Btu/hr
Airflow (20F delta T)	=	144	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	86.50	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	406	Btu/hr				
Glass	37.50	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	1,258	Btu/hr				
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr				
Door	0	ft	x	7.00	ft	x	61	F x 0.80	Btu/hr ft2 F	=	0	Btu/hr			
Roof	171	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	522	Btu/hr				
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr				
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr				
Infiltration	118	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH x 0.017	min/hr	=	634	Btu/hr

Heating	=	2,820	Btu/hr
Safety Factor (25%)	=	705	Btu/hr
MIN HEATING	=	3,525	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.09	Btu/lb	@	78.70	F DB	,	65.25	F WB	,	7	% OA	=	4,487	Btu/hr
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB				=		
	Cooling Cap	144	CFM	x	6.92	BTU/lb	x	4.5					=		
													=	0.4	Tons
													=	1	GPM
													=	316	ft2/Ton
	Mix Air T-In	66	F	@	7	% OA							=		
	Heat Air T-Out	95	F										=		
	Heating Cap	144	CFM	x	29	F	x	1.08					=	4,497	Btu/hr

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b> 1 of 1
<b>Trade Specification Section:</b> 15500	232 PLANNER	<b>Date</b>
<b>By:</b>	<b>Checked By:</b>	<b>Project No.:</b> 17076
		00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b> (°F-Db/°F-Wb) 75	63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b> (°F-Db/°F-Wb) 88	74	9 °F

### I. Outdoor Air Requirement

Area	Method	110	ft2																
Ventilation	per Person	0.06	x	110															9.35 CFM
	per ACH	2.00	x	0	ft2	x	12.00	ft	/	60	min/hr	=							0 CFM

### II. Sensible Cooling Load

Walls	N	11	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F			=	206	Btu/hr		
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr		
	E	3	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F			=	76	Btu/hr		
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr		
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr		
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr		
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr		
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F			=	0	Btu/hr		
Glass	N	3	ft	x	5	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	398	Btu/hr	
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr	
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr	
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr	
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr	
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr	
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr	
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr	
Glass		3	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F			=	96	Btu/hr		
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F			=	0	Btu/hr		
Roof		160	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F					=	319	Btu/hr			
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F					=	0	Btu/hr			
Lighting/Power		110	ft2	x	2.00	W/ft2	x	3.412	Btu/h/Watt					=	751	Btu/hr			
People		1	People	x	255	Btu/hr	x	1	Diversity					=	140	Btu/hr			
Infiltration		110	ft2	x	12.00	ft	x	13	F	x	1.08	x	0.4 ACH	x	0.017	min/hr	=	126	Btu/hr
<b>RSH</b>																=	2,113	Btu/hr	
<b>Safety Factor (15%)</b>																=	317	Btu/hr	
<b>ERSH</b>																=	2,430	Btu/hr	
<b>Airflow (20F delta T)</b>																=	112	CFM	

*Sensible(w/o treating air)*

### III. Heating Load

Walls					148.42	ft2	x	61	F	x	0.08	Btu/hr ft2 F			=	696	Btu/hr		
Glass					12.50	ft2	x	61	F	x	0.55	Btu/hr ft2 F			=	419	Btu/hr		
Skylight					0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F			=	0	Btu/hr		
Door		0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F			=	0	Btu/hr		
Roof		160	ft2	x	61	F	x	0.05	Btu/hr ft2 F					=	486	Btu/hr			
Floor		0	ft2	x	61	F	x	0.03	Btu/hr ft2 F					=	0	Btu/hr			
Slab		0	ft	x	61	F	x	0.10	Btu/hr ft2 F					=	0	Btu/hr			
Infiltration		110	ft2	x	12.00	ft	x	61	F	x	1.08	x	0.4 ACH	x	0.017	min/hr	=	591	Btu/hr
<b>Heating</b>																=	2,194	Btu/hr	
<b>Safety Factor (25%)</b>																=	548	Btu/hr	
<b>MIN HEATING</b>																=	2,742	Btu/hr	

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	30.19	Btu/lb	@	78.83	F DB	,	65.38	F WB	,	8	% OA						
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB									
	Cooling Cap	112	CFM	x	7.01	BTU/lb	x	4.5							=	3,550	Btu/hr	
															=	0.3	Tons	
															=	1	GPM	
															=	372	ft2/Ton	
	Mix Air T-In	65	F	@	8	% OA												
	Heat Air T-Out	95	F															
	Heating Cap	112	CFM	x	30	F	x	1.08							=	3,601	Btu/hr	



# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b>
<b>Trade Specification Section:</b> 15500	~	<b>1 of 1</b>
<b>By:</b>	<b>Checked By:</b>	<b>Date</b>
	<b>Project No.:</b> 17076	00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	<b>Indoor</b>	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	<b>Outdoor</b>	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P	min/hr	=	0 CFM
Ventilation	per Person	0.06	x	0	+	5	x	0	0 CFM
	per ACH	2.00 ACH	x	0	ft2	x	12.00	ft	/
								60	=

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr		
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr		
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr		
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr		
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr		
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr		
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr		
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr		
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr			
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr			
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	0	Btu/hr				
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr				
Lighting/Power		0	ft2	x	2.00	W/ft2	x	3.412	Btu/h/Watt			=	0	Btu/hr				
People		0	People	x	255	Btu/hr	x	1	Diversity			=	0	Btu/hr				
Infiltration		0	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	0	Btu/hr

<b>RSH</b>	=	0	Btu/hr
<b>Safety Factor (15%)</b>	=	0	Btu/hr
<b>ERSH</b>	=	0	Btu/hr
<b>Airflow (20F delta T)</b>	=	0	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	0.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	0	Btu/hr						
Glass	0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr						
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr						
Door	0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F						
Roof	0	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	0	Btu/hr						
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr						
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr						
Infiltration	0	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	0	Btu/hr

<b>Heating</b>	=	0	Btu/hr
<b>Safety Factor (25%)</b>	=	0	Btu/hr
<b>MIN HEATING</b>	=	0	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	0.00	Btu/lb	@	0.00	F DB	,	0.00	F WB	,	100	% OA	=	0	Btu/hr
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB				=		
	Cooling Cap	0	CFM	x	-23.17	BTU/lb	x	4.5					=	0	Btu/hr
													=	0.0	Tons
													=	0	GPM
													=	0	ft2/Ton
	Mix Air T-In	9	F	@	100	% OA							=		
	Heat Air T-Out	#DIV/0!	F										=	#DIV/0!	Btu/hr
	Heating Cap	0	CFM	x	#DIV/0!	F	x	1.08					=		

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b>
<b>Trade Specification Section:</b> 15500	~	1 of 1
<b>By:</b>	<b>Checked By:</b>	<b>Date</b>
	<b>Project No.:</b> 17076	00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	Indoor	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	Outdoor	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P	=	0	CFM
Ventilation	per Person	0.06	x	0	+	5	x	0	0 CFM
	per ACH	2.00	x	0	ft2	x	12.00	ft	/
								60	min/hr
								=	0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC x 0.80	CLF	=	0	Btu/hr		
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC x 0.65	CLF	=	0	Btu/hr		
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.37	CLF	=	0	Btu/hr		
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC x 0.29	CLF	=	0	Btu/hr		
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.30	CLF	=	0	Btu/hr		
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.40	CLF	=	0	Btu/hr		
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC x 0.21	CLF	=	0	Btu/hr		
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC x 0.44	CLF	=	0	Btu/hr		
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr			
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr			
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F			=	0	Btu/hr				
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F			=	0	Btu/hr				
Lighting/Power		0	ft2	x	2.00	W/ft2	x	3.412	Btu/h/Watt			=	0	Btu/hr				
People		0	People	x	255	Btu/hr	x	1	Diversity			=	0	Btu/hr				
Infiltration		0	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	0	Btu/hr

<b>RSH</b>	=	0	Btu/hr
<b>Safety Factor (15%)</b>	=	0	Btu/hr
<b>ERSH</b>	=	0	Btu/hr
<b>Airflow (20F delta T)</b>	=	0	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	0.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	0	Btu/hr						
Glass	0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr						
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr						
Door	0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F						
Roof	0	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	0	Btu/hr						
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr						
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr						
Infiltration	0	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	0	Btu/hr

<b>Heating</b>	=	0	Btu/hr
<b>Safety Factor (25%)</b>	=	0	Btu/hr
<b>MIN HEATING</b>	=	0	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	0.00	Btu/lb	@	0.00	F DB	,	0.00	F WB	,	100	% OA	=	0	Btu/hr
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB				=		
	Cooling Cap	0	CFM	x	-23.17	BTU/lb	x	4.5					=	0	Btu/hr
													=	0.0	Tons
													=	0	GPM
													=	0	ft2/Ton
	Mix Air T-In	9	F	@	100	% OA							=		
	Heat Air T-Out	#DIV/0!	F										=		
	Heating Cap	0	CFM	x	#DIV/0!	F	x	1.08					=	#DIV/0!	Btu/hr

# BLW

BLW ENGINEERS, INC.

311 Great Road, PO Box 1551 Littleton, Massachusetts 01460 tel 978.486.4301 fax 978.428.0067 e-mail Info@blwengineers.com

## HVAC Calculations

<b>Project phase:</b> Preliminary	<b>Project:</b> Boxford	<b>Sheet</b>
<b>Trade Specification Section:</b> 15500	~	1 of 1
<b>By:</b>	<b>Checked By:</b>	<b>Date</b>
	<b>Project No.:</b> 17076	00.00.00

<b>Design Conditions:</b>			
<b>Location</b>	<b>Temps.</b>	<b>Summer</b>	<b>Winter</b>
-	Indoor	(°F-Db/°F-Wb) 75 63	70 °F IMC 2012, IECC 2012
	Outdoor	(°F-Db/°F-Wb) 88 74	9 °F

### I. Outdoor Air Requirement

Area	Method	Ra	ft2	A	Rp	P	min/hr	=	0 CFM
Ventilation	per Person	0.06	x	0	+	5	x	0	0 CFM
	per ACH	2.00	x	0	ft2	x	12.00	ft	/
								60	=
									0 CFM

### II. Sensible Cooling Load

Walls	N	0	ft	x	12.00	ft	x	23	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	S	0	ft	x	12.00	ft	x	46	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	E	0	ft	x	12.00	ft	x	31	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	W	0	ft	x	12.00	ft	x	41	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	NE	0	ft	x	12.00	ft	x	29	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	SE	0	ft	x	12.00	ft	x	37	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	NW	0	ft	x	12.00	ft	x	19	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
	SW	0	ft	x	12.00	ft	x	26	CLTD	x	0.08	Btu/hr ft2 F	=	0	Btu/hr			
Glass	N	0	ft	x	5	ft	x	48	SHG	x	0.83	SC	x	0.80	CLF	=	0	Btu/hr
	S	0	ft	x	5	ft	x	149	SHG	x	0.83	SC	x	0.65	CLF	=	0	Btu/hr
	E	0	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.37	CLF	=	0	Btu/hr
	W	0	ft	x	5	ft	x	216	SHG	x	0.83	SC	x	0.29	CLF	=	0	Btu/hr
	NE	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.30	CLF	=	0	Btu/hr
	SE	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.40	CLF	=	0	Btu/hr
	NW	0	ft	x	5	ft	x	172	SHG	x	0.83	SC	x	0.21	CLF	=	0	Btu/hr
	SW	0	ft	x	5	ft	x	161	SHG	x	0.83	SC	x	0.44	CLF	=	0	Btu/hr
Glass		0	ft	x	5.00	ft	x	14	CLTD	x	0.55	Btu/hr ft2 F	=	0	Btu/hr			
Skylight		0	ft	x	1.00	ft	x	40	CLTD	x	0.40	Btu/hr ft2 F	=	0	Btu/hr			
Roof		0	ft2	x	40.00	CLTD	x	0.05	Btu/hr ft2 F	=	0	Btu/hr						
Floor		0	ft2	x	4.00	CLTD	x	0.03	Btu/hr ft2 F	=	0	Btu/hr						
Lighting/Power		0	ft2	x	2.00	W/ft2	x	3.412	Btu/h/Watt	=	0	Btu/hr						
People		0	People	x	255	Btu/hr	x	1	Diversity	=	0	Btu/hr						
Infiltration		0	ft2	x	12.00	ft	x	13	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	0	Btu/hr

<b>RSH</b>	=	0	Btu/hr
<b>Safety Factor (15%)</b>	=	0	Btu/hr
<b>ERSH</b>	=	0	Btu/hr
<b>Airflow (20F delta T)</b>	=	0	CFM

*Sensible(w/o treating air)*

### III. Heating Load

Walls	0.00	ft2	x	61	F	x	0.08	Btu/hr ft2 F	=	0	Btu/hr						
Glass	0.00	ft2	x	61	F	x	0.55	Btu/hr ft2 F	=	0	Btu/hr						
Skylight	0.00	ft2	x	61	F	x	0.40	Btu/hr ft2 F	=	0	Btu/hr						
Door	0	ft	x	7.00	ft	x	61	F	x	0.80	Btu/hr ft2 F						
Roof	0	ft2	x	61	F	x	0.05	Btu/hr ft2 F	=	0	Btu/hr						
Floor	0	ft2	x	61	F	x	0.03	Btu/hr ft2 F	=	0	Btu/hr						
Slab	0	ft	x	61	F	x	0.10	Btu/hr ft2 F	=	0	Btu/hr						
Infiltration	0	ft2	x	12.00	ft	x	61	F	x	1.08	x 0.4 ACH	x	0.017	min/hr	=	0	Btu/hr

<b>Heating</b>	=	0	Btu/hr
<b>Safety Factor (25%)</b>	=	0	Btu/hr
<b>MIN HEATING</b>	=	0	Btu/hr

(not treating air)

### IV. Furnace Specifications

AHU	Enthalpy-In	0.00	Btu/lb	@	0.00	F DB	,	0.00	F WB	,	100	% OA	=	0	Btu/hr
	Enthalpy-Out	23.17	Btu/lb	@	56.00	F DB	,	55.0	F WB				=		
	Cooling Cap	0	CFM	x	-23.17	BTU/lb	x	4.5					=	0	Btu/hr
													=	0.0	Tons
													=	0	GPM
													=	0	ft2/Ton
	Mix Air T-In	9	F	@	100	% OA							=		
	Heat Air T-Out	#DIV/0!	F										=		
	Heating Cap	0	CFM	x	#DIV/0!	F	x	1.08					=	#DIV/0!	Btu/hr